

EMISSIONS INFORMATION

PURSUANT TO THE ENVIRONMENTAL INFORMATION ACT

Facility	Parameter	Measurement [mg/m ³]	Limit value [mg/m ³]
Regenerative afterburner	Organic C	2,6	20
(Date of measurement: 15.07.2026)	Carbon monoxide (CO)	6,7	100
Legally required: 1-year interval	Nitrogen oxides (NO _x)	82,6	100
	Dust	0,3	5
	Hydrogen fluoride (HF)	0,4	5
	Hydrogen chloride (HCl)	0,4	5
	Sulfur dioxide (SO ₂)	0,86	200
Regenerative afterburner 2	Carbon monoxide (CO)	7,3	10
(Date of measurement: 26.06.2025)			
Legally required: 3-year interval	Nitrogen oxides (NO _x)	1,2	10
	Organic C	4,4	10
	Hydrogen fluoride (HF)	<0,2	5
	Hydrogen chloride (HCl)	<0,2	5
	Dust	<0,3	5

EMISSIONS INFORMATION

PURSUANT TO THE ENVIRONMENTAL INFORMATION ACT

Facility	Parameter	Measurement [mg/m ³]	Limit value [mg/m ³]
Biofilter 1/2	Ammonia (NH ₃)	8,6/5,4	30
(Date of measurement: 02.07.2025)	Phenols	0,03/0,05	20
Legally required: 3-year interval	Formaldehyde	<0,10/<0,2	20
Biofilter 3 (Plant 5) (18.07.2025)	Organic C	5,7	20
Legally required: 3-year interval			
HESO scrubber (Plant 5) (14.07.2026)	Sulfuric acid (H ₂ SO ₄)	0,38	1
Legally required: 2-year interval	Hydrogen chloride (HCl)	0,25	8
Fabric filter (Plant 5) (14.07.2026)	Dust	0,3	5
Legally required: 1-year interval			