

Permit Reference Number : PPC/A/1157446


Operator : Kanadevia Inova UK Operations Ltd

Installation: Earlsgate Energy Center

Form Number: Air 3 (A1)

Reporting of Continuously Monitored Emissions to Air for HCl mg/Nm3 at Emission Point A1 For the month of January 2026

Daily and Half-hourly Average Monitoring Data



Monthly summary		Date	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24	25	26	27	28	29	30	31		
Half-hourly average		Half-hourly average ELV	60.0	60.0	60.0	60.0	60.0	60.0	60.0	60.0	60.0	60.0	60.0	60.0	60.0	60.0	60.0	60.0	60.0	60.0	60.0	60.0	60.0	60.0	60.0	60.0	60.0	60.0	60.0	60.0	60.0	60.0	60.0		
	Monthly maximum	9.1	Maximum Half-hourly average	7.3	7.3	7.3	7.6	7.5	8.3	7.9	7.5	7.5	7.3	7.4	7.6	7.4	7.5	7.4	4.5	5.9	7.4	7.5	9.1	7.5	Off	Off	3.7	3.1	2.9	3.3	3.9	4.6	3.8	3.2	
	Monthly mean	5.4	Mean Half-hourly average	6.5	6.5	6.1	6.6	6.7	6.9	6.8	6.8	6.9	6.7	6.8	7.0	6.8	6.7	6.1	3.6	4.0	6.9	6.9	6.9	6.5	Off	Off	3.3	2.0	2.2	2.7	3.1	3.4	3.1	2.2	
	Monthly minimum	1.5	Minimum Half-hourly average	5.7	5.7	5.3	4.9	5.7	6.2	5.9	5.8	6.3	5.5	5.9	6.1	5.3	5.5	4.2	3.1	3.1	6.3	6.1	5.6	4.0	Off	Off	2.9	1.5	1.7	2.2	2.7	2.7	2.1	1.8	
	Total Invalid results	0	No of Invalid results	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
	Sum of exceedances	0	No of exceedances of ELV	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
Daily average		Daily average ELV	8.0	8.0	8.0	8.0	8.0	8.0	8.0	8.0	8.0	8.0	8.0	8.0	8.0	8.0	8.0	8.0	8.0	8.0	8.0	8.0	8.0	8.0	8.0	8.0	8.0	8.0	8.0	8.0	8.0	8.0	8.0	8.0	
	Monthly maximum	7.0	Daily average	6.5	6.5	6.1	6.6	6.7	6.9	6.8	6.8	6.9	6.7	6.8	7.0	6.8	6.7	6.1	3.6	4.0	6.9	6.9	6.9	6.5	Off	Off	3.3	2.0	2.2	2.7	3.1	3.4	3.1	2.2	
	No of invalid days	0	Value Valid?	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	
	Sum of exceedances	0	Value Exceeds ELV?	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N

Signed.....

Date.....

(Authorised to sign as a representative of the Operator)

Permit Reference Number : PPC/A/1157446


Operator : Kanadevia Inova UK Operations Ltd

Installation: Earlsgate Energy Center

Form Number: Air 5 (A1)

Reporting of Continuously Monitored Emissions to Air for SO2 mg/Nm3 at Emission Point A1 For the month of January 2026

Daily and Half-hourly Average Monitoring Data



Monthly summary		Date	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24	25	26	27	28	29	30	31		
Half-hourly average		Half-hourly average ELV	200	200	200	200	200	200	200	200	200	200	200	200	200	200	200	200	200	200	200	200	200	200	200	200	200	200	200	200	200	200	200		
	Monthly maximum	42	Maximum Half-hourly average	7	8	7	10	5	6	5	6	8	5	7	6	6	6	8	11	13	6	5	5	7	Off	Off	27	29	29	13	9	15	42	30	
	Monthly mean	6	Mean Half-hourly average	5	6	5	6	4	5	5	5	5	4	5	5	5	6	6	5	5	4	4	5	Off	Off	22	10	6	6	6	7	13	8		
	Monthly minimum	3	Minimum Half-hourly average	5	4	4	4	4	4	4	4	4	3	4	4	4	4	5	5	3	4	4	3	4	Off	Off	15	4	4	4	5	5	5	4	
	Total Invalid results	0	No of Invalid results	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
	Sum of exceedances	0	No of exceedances of ELV	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	Off	Off	0	0	0	0	0	0	0	0
Daily average		Daily average ELV	40	40	40	40	40	40	40	40	40	40	40	40	40	40	40	40	40	40	40	40	40	40	40	40	40	40	40	40	40	40	40		
	Monthly maximum	22	Daily average	5	6	5	6	4	5	5	5	5	4	5	5	5	6	6	5	5	4	4	5	Off	Off	22	10	6	6	6	7	13	8		
	No of invalid days	0	Value Valid?	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y		
	Sum of exceedances	0	Value Exceeds ELV?	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	

Signed.....

Date.....

(Authorised to sign as a representative of the Operator)


Permit Reference Number : PPC/A/1157446

Operator : Kanadevia Inova UK Operations Ltd

Installation: Earlsgate Energy Center

Form Number: Air 6 (A1)

Reporting of Continuously Monitored Emissions to Air for NOx mg/Nm3 at Emission Point A1 For the month of January 2026



Monthly summary		Date	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24	25	26	27	28	29	30	31		
Half-hourly average		Half-hourly average ELV	400	400	400	400	400	400	400	400	400	400	400	400	400	400	400	400	400	400	400	400	400	400	400	400	400	400	400	400	400	400	400	400	
	Monthly maximum	184	Maximum Half-hourly average	170	163	168	172	167	172	171	171	180	168	165	164	166	177	172	166	172	173	168	184	177	Off	Off	161	180	182	165	166	177	174	172	
	Monthly mean	152	Mean Half-hourly average	153	151	151	151	152	154	153	152	154	153	150	153	151	155	150	152	153	151	153	152	149	Off	Off	156	154	150	153	153	152	151	152	
	Monthly minimum	93	Minimum Half-hourly average	132	140	135	131	136	118	129	125	126	142	117	143	124	144	122	138	136	116	134	138	113	Off	Off	152	123	104	135	139	128	93	127	
	Total Invalid results	0	No of Invalid results	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
	Sum of exceedances	0	No of exceedances of ELV	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
Daily average		Daily average ELV	180	180	180	180	180	180	180	180	180	180	180	180	180	180	180	180	180	180	180	180	180	180	180	180	180	180	180	180	180	180	180	180	
	Monthly maximum	156	Daily average	153	151	151	151	152	154	153	152	154	153	150	153	151	155	150	152	153	151	153	152	149	Off	Off	156	154	150	153	153	152	151	152	
	No of invalid days	0	Value Valid?	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	
	Sum of exceedances	0	Value Exceeds ELV?	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N

Signed.....

Date.....

(Authorised to sign as a representative of the Operator)

Permit Reference Number : PPC/A/1157446


Operator : Kanadevia Inova UK Operations Ltd

Installation: Earlsgate Energy Center

Form Number: Air 2 (A1)

Reporting of Continuously Monitored Emissions to Air for TOC mg/Nm3 at Emission Point A1 For the month of January 2026

Daily and Half-hourly Average Monitoring Data



Monthly summary		Date	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24	25	26	27	28	29	30	31		
Half-hourly average		Half-hourly average ELV	20.0	20.0	20.0	20.0	20.0	20.0	20.0	20.0	20.0	20.0	20.0	20.0	20.0	20.0	20.0	20.0	20.0	20.0	20.0	20.0	20.0	20.0	20.0	20.0	20.0	20.0	20.0	20.0	20.0	20.0	20.0		
	Monthly maximum	487.4	Maximum Half-hourly average	4.1	4.0	40.7	6.0	3.9	4.6	4.8	3.7	4.7	4.2	9.7	4.9	6.1	4.3	8.3	3.6	20.8	4.2	3.9	3.7	3.5	Off	Off	6.8	7.4	487.4	5.2	4.3	4.5	11.8	5.4	
	Monthly mean	3.5	Mean Half-hourly average	3.1	3.2	3.6	2.5	2.6	3.0	3.1	2.2	2.6	3.2	3.7	3.6	3.7	3.5	2.9	2.5	3.2	2.9	2.7	2.6	2.2	Off	Off	6.1	4.4	13.4	3.0	3.0	3.3	3.4	3.6	
	Monthly minimum	0.9	Minimum Half-hourly average	2.5	2.3	2.0	1.3	1.8	2.0	1.7	0.9	1.0	2.4	2.5	2.5	1.7	2.7	1.7	1.8	1.9	1.9	2.0	1.6	1.2	Off	Off	4.9	2.9	1.3	2.2	2.1	2.2	1.7	2.3	
	Total Invalid results	0	No of Invalid results	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
	Sum of exceedances	3	No of exceedances of ELV	0	0	1	0	0	0	0	0	0	0	0	0	0	0	0	0	0	1	0	0	0	0	Off	Off	0	0	1	0	0	0	0	0
Daily average		Daily average ELV	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	
	Monthly maximum	13.4	Daily average	3.1	3.2	3.6	2.5	2.6	3.0	3.1	2.2	2.6	3.2	3.7	3.6	3.7	3.5	2.9	2.5	3.2	2.9	2.7	2.6	2.2	Off	Off	6.1	4.4	13.4	3.0	3.0	3.3	3.4	3.6	
	No of invalid days	0	Value Valid?	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	
	Sum of exceedances	1	Value Exceeds ELV?	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	Y	N	N	N	N	N	

Signed.....

Date.....

(Authorised to sign as a representative of the Operator)

Permit Reference Number : PPC/A/1157446


Operator : Kanadevia Inova UK Operations Ltd

Installation: Earlsgate Energy Center

Form Number: Air 7 (A1)

Reporting of Continuously Monitored Emissions to Air for NH3 mg/Nm3 at Emission Point A1 For the month of January 2026

Daily and Half-hourly Average Monitoring Data



Monthly summary		Date	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24	25	26	27	28	29	30	31			
Half-hourly average		Half-hourly average ELV	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
	Monthly maximum	18.0	Maximum Half-hourly average	0.3	0.1	0.7	0.6	0.1	0.2	0.1	0.1	0.1	0.1	0.4	0.2	0.2	0.2	0.5	0.2	1.2	0.2	0.2	0.2	0.2	0.3	Off	Off	0.6	0.5	18.0	1.8	0.3	0.3	1.7	0.4	
	Monthly mean	0.2	Mean Half-hourly average	0.1	0.0	0.1	0.1	0.0	0.0	0.0	0.1	0.0	0.0	0.1	0.1	0.1	0.1	0.2	0.1	0.1	0.1	0.1	0.1	0.1	0.1	Off	Off	0.4	0.3	1.1	0.5	0.2	0.2	0.3	0.2	
	Monthly minimum	0.0	Minimum Half-hourly average	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.1	0.0	0.0	0.0	0.0	0.0	0.0	Off	Off	0.3	0.1	0.2	0.2	0.2	0.0	0.1	0.1		
	Total Invalid results	0	No of Invalid results	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
	Sum of exceedances	0	No of exceedances of ELV	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	Off	Off	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Daily average		Daily average ELV	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0		
	Monthly maximum	1.1	Daily average	0.1	0.0	0.1	0.1	0.0	0.0	0.0	0.1	0.0	0.0	0.1	0.1	0.1	0.1	0.2	0.1	0.1	0.1	0.1	0.1	0.1	0.1	Off	Off	0.4	0.3	1.1	0.5	0.2	0.2	0.3	0.2	
	No of invalid days	0	Value Valid?	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	
	Sum of exceedances	0	Value Exceeds ELV?	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	

Signed.....

Date.....

(Authorised to sign as a representative of the Operator)

Permit Reference Number : PPC/A/1157446


Operator : Kanadevia Inova UK Operations Ltd

Installation: Earlsgate Energy Center

Form Number: Air 1 (A1)

Reporting of Continuously Monitored Emissions to Air for Particulates mg/Nm3 at Emission Point A1 For the month of January 2026

Daily and Half-hourly Average Monitoring Data



Monthly summary		Date	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24	25	26	27	28	29	30	31		
Half-hourly average		Half-hourly average ELV	30.0	30.0	30.0	30.0	30.0	30.0	30.0	30.0	30.0	30.0	30.0	30.0	30.0	30.0	30.0	30.0	30.0	30.0	30.0	30.0	30.0	30.0	30.0	30.0	30.0	30.0	30.0	30.0	30.0	30.0	30.0	30.0	
	Monthly maximum	0.2	Maximum Half-hourly average	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.2	0.1	0.1	0.1	0.1		
	Monthly mean	0.1	Mean Half-hourly average	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	
	Monthly minimum	0.1	Minimum Half-hourly average	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	
	Total Invalid results	0	No of Invalid results	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
	Sum of exceedances	0	No of exceedances of ELV	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
Daily average		Daily average ELV	5.0	5.0	5.0	5.0	5.0	5.0	5.0	5.0	5.0	5.0	5.0	5.0	5.0	5.0	5.0	5.0	5.0	5.0	5.0	5.0	5.0	5.0	5.0	5.0	5.0	5.0	5.0	5.0	5.0	5.0	5.0	5.0	
	Monthly maximum	0.1	Daily average	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	
	No of invalid days	0	Value Valid?	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	
	Sum of exceedances	0	Value Exceeds ELV?	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N

Signed.....

Date.....

(Authorised to sign as a representative of the Operator)


Permit Reference Number : PPC/A/1157446

Operator : Kanadevia Inova UK Operations Ltd

Installation: Earlsgate Energy Center

Form Number: Air 8 (A1)

Reporting of Continuously Monitored Emissions to Air for N2O mg/Nm3 at Emission Point A1 For the month of January 2026



Monthly summary		Date	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24	25	26	27	28	29	30	31		
Half-hourly average		Half-hourly average ELV	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	Monthly maximum	11.2	Maximum Half-hourly average	10.0	4.1	3.0	5.3	2.7	3.9	3.2	3.3	3.2	2.1	3.5	5.2	4.0	3.1	10.5	3.5	4.2	3.8	2.7	3.6	11.2	Off	Off	2.3	5.1	9.2	3.8	3.8	5.1	5.7	4.0	
	Monthly mean	2.2	Mean Half-hourly average	2.7	2.0	1.8	1.6	1.3	1.6	1.7	2.1	1.7	1.4	2.1	2.8	2.4	2.1	3.1	2.3	2.0	1.7	1.7	2.2	3.2	Off	Off	1.7	2.6	2.8	2.7	2.7	2.5	2.4	2.5	
	Monthly minimum	0.2	Minimum Half-hourly average	0.8	0.8	0.7	0.2	0.5	0.4	1.0	1.0	0.7	0.3	1.1	1.7	0.9	1.2	1.6	1.4	0.9	0.7	0.8	0.8	0.9	Off	Off	1.1	0.6	0.8	1.8	1.7	1.3	0.4	1.4	
	Total Invalid results	0	No of Invalid results	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
	Sum of exceedances	0	No of exceedances of ELV	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	Off	Off	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Daily average		Daily average ELV	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	Monthly maximum	3.2	Daily average	2.7	2.0	1.8	1.6	1.3	1.6	1.7	2.1	1.7	1.4	2.1	2.8	2.4	2.1	3.1	2.3	2.0	1.7	1.7	2.2	3.2	Off	Off	1.7	2.6	2.8	2.7	2.7	2.5	2.4	2.5	
	No of invalid days	0	Value Valid?	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	
	Sum of exceedances	0	Value Exceeds ELV?	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N


Signed.....

Date.....

(Authorised to sign as a representative of the Operator)

Reporting of Continuously Monitored Emissions to Air for CO mg/Nm3 at Emission Point A1 For the month of January 2026

Daily and 10 Minute Average Monitoring Data



Monthly summary		Date	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24	25	26	27	28	29	30	31		
10 Minute average		10 Minute average ELV (95th Percentile)	150	150	150	150	150	150	150	150	150	150	150	150	150	150	150	150	150	150	150	150	150	150	150	150	150	150	150	150	150	150	150		
	Monthly Maximum 10-min	1154	Maximum 10 Minute average	8	47	403	328	113	108	296	73	71	30	647	74	457	114	267	40	1118	126	192	24	163	Off	Off	87	408	880	56	97	90	1154	327	
	Monthly mean 10-min avgs	10	95th Percentile	6	9	47	113	14	7	9	6	8	6	27	9	10	9	14	7	22	32	13	6	7	Off	Off	12	76	94	9	7	12	157	26	
	Monthly Minimum 10-min	0	Minimum 10 Minute average	2	2	1	1	1	2	1	1	1	2	3	2	2	2	2	1	1	1	1	1	0	Off	Off	6	3	0	2	2	2	1	1	
	Total Invalid results	2	No of Invalid results	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	2	0	0	0	0	0	0	0
			Number of results above 150mg/m³	0	0	3	7	0	0	3	0	0	0	2	0	2	0	1	0	2	0	1	0	1	Off	Off	0	3	6	0	0	0	0	9	1
		Sum of Exceedances of 95th percentile ELV	1																																
Daily average		Daily average ELV	50	50	50	50	50	50	50	50	50	50	50	50	50	50	50	50	50	50	50	50	50	50	50	50	50	50	50	50	50	50	50	50	
	Monthly maximum	34	Daily average	4	5	13	16	5	5	10	4	5	4	16	6	11	7	8	4	20	7	6	4	5	Off	Off	24	18	24	6	6	7	34	11	
	No of invalid days	0	Value Valid?	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	
	Sum of exceedances	0	Value Exceeds ELV? (Y/N)	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N

Signed.....

Date.....

(Authorised to sign as a representative of the Operator)

Environment Agency explanatory note: The 10-minute average ELV is based on the "95th percentile" In this case this means that 95% of the 10 minute averages in the calendar day (= 137) must be below 150 mg/m3, and 5% (= 7) are allowed to be any value above 150 mg/m3. Whilst we expect operators to minimise CO emissions at all times, it is perfectly acceptable for the value of the maximum 10-minute average to be above 150 mg/m3, provided the 95th percentile ELV has been met for that period


Permit Reference Number : PPC/A/1157446

Operator : Kanadevia Inova UK Operations Ltd

Installation: Earlsgate Energy Center

Form Number: Air A (A1)

Reporting of Continuously Monitored Emissions to Air for CO2 % at Emission Point A1 For the month of January 2026



Monthly summary		Date	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24	25	26	27	28	29	30	31		
Half-hourly average		Half-hourly average ELV	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
	Monthly maximum	8.8	Maximum Half-hourly average	8.5	8.3	8.5	8.4	8.5	8.8	8.4	8.4	8.3	8.5	8.5	8.3	8.3	8.3	8.4	8.6	8.5	8.4	8.6	8.2	Off	Off	8.3	8.4	8.4	8.3	8.3	8.4	8.4	8.5		
	Monthly mean	8.2	Mean Half-hourly average	8.2	8.2	8.3	8.3	8.3	8.3	8.2	8.2	8.2	8.3	8.2	8.1	8.2	8.2	8.2	8.2	8.3	8.3	8.3	8.2	8.1	Off	Off	8.2	8.2	8.2	8.2	8.2	8.2	8.2	8.2	
	Monthly minimum	6.8	Minimum Half-hourly average	8.1	8.2	8.2	8.2	8.2	8.1	8.1	8.1	8.1	8.2	8.0	8.0	8.1	8.1	8.1	8.2	8.1	8.0	8.2	8.1	7.7	Off	Off	8.2	8.0	6.8	8.1	8.1	8.1	8.1	8.0	
	Total Invalid results	0	No of Invalid results	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
	Sum of exceedances	0	No of exceedances of ELV	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Daily average		Daily average ELV	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
	Monthly maximum	8.3	Daily average	8.2	8.2	8.3	8.3	8.3	8.3	8.2	8.2	8.2	8.3	8.2	8.1	8.2	8.2	8.2	8.2	8.3	8.3	8.3	8.2	8.1	Off	Off	8.2	8.2	8.2	8.2	8.2	8.2	8.2	8.2	
	No of invalid days	0	Value Valid?	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	
	Sum of exceedances	0	Value Exceeds ELV?	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N

Signed.....

Date.....

(Authorised to sign as a representative of the Operator)

Permit Reference Number : PPC/A/1157446


Operator : Kanadevia Inova UK Operations Ltd

Installation: Earlsgate Energy Center

Form Number: Air B (A1)

Reporting of Continuously Monitored Emissions to Air for Dry Oxygen % at Emission Point A1 For the month of January 2026

Daily and Half-hourly Average Monitoring Data



Monthly summary		Date	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24	25	26	27	28	29	30	31		
Half-hourly average		Half-hourly average ELV	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
	Monthly maximum	9.4	Maximum Half-hourly average	8.9	7.2	7.1	7.7	7.0	6.9	6.9	7.0	6.7	6.8	7.0	6.9	6.8	7.0	7.7	6.8	7.3	6.9	6.8	6.9	9.0	Off	Off	6.1	6.7	9.4	6.7	6.8	6.9	7.0	6.8	
	Monthly mean	6.4	Mean Half-hourly average	6.6	6.6	6.5	6.5	6.5	6.4	6.4	6.4	6.4	6.4	6.5	6.5	6.5	6.5	6.5	6.4	6.5	6.5	6.4	6.5	6.6	Off	Off	6.0	6.3	6.5	6.3	6.3	6.4	6.3	6.4	
	Monthly minimum	5.3	Minimum Half-hourly average	5.5	6.1	5.7	5.5	5.9	6.0	5.7	5.9	5.9	5.6	6.1	6.1	6.1	6.2	5.8	6.1	5.9	6.0	6.0	6.0	5.3	Off	Off	5.8	5.7	5.3	6.0	6.0	5.7	5.5	5.7	
	Total Invalid results	0	No of Invalid results	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
	Sum of exceedances	0	No of exceedances of ELV	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	Off	Off	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Daily average		Daily average ELV	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
	Monthly maximum	6.6	Daily average	6.6	6.6	6.5	6.5	6.5	6.4	6.4	6.4	6.4	6.4	6.5	6.5	6.5	6.5	6.5	6.4	6.5	6.5	6.4	6.5	6.6	Off	Off	6.0	6.3	6.5	6.3	6.3	6.4	6.3	6.4	
	No of invalid days	0	Value Valid?	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	
	Sum of exceedances	0	Value Exceeds ELV?	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N

Signed.....

Date.....

(Authorised to sign as a representative of the Operator)


Permit Reference Number : PPC/A/1157446

Operator : Kanadevia Inova UK Operations Ltd

Installation: Earlsgate Energy Center

Form Number: Air C (A1)

Reporting of Continuously Monitored Emissions to Air for Moisture % at Emission Point A1 For the month of January 2026



Monthly summary		Date	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24	25	26	27	28	29	30	31		
Half-hourly average		Half-hourly average ELV	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
	Monthly maximum	25.0	Maximum Half-hourly average	20.6	19.5	20.2	18.9	21.9	19.7	19.6	20.0	19.6	20.1	19.9	20.5	20.6	21.5	21.5	20.4	21.0	21.0	20.6	21.1	20.9	Off	Off	18.6	20.1	22.5	23.8	24.7	25.0	22.0	23.8	
	Monthly mean	18.0	Mean Half-hourly average	17.7	17.5	17.6	17.2	17.4	17.7	17.6	17.7	17.5	17.7	17.4	18.0	18.1	18.3	18.5	18.2	18.0	17.8	18.1	18.4	18.3	Off	Off	18.0	17.8	17.9	19.0	19.5	19.3	18.7	17.8	
	Monthly minimum	11.8	Minimum Half-hourly average	15.1	15.5	16.4	14.1	15.4	15.4	15.6	15.8	15.6	16.2	15.4	16.4	16.3	16.7	16.1	17.0	15.9	15.8	17.0	16.2	13.6	Off	Off	16.7	15.4	11.8	18.0	17.8	16.6	15.9	15.4	
	Total Invalid results	0	No of Invalid results	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
	Sum of exceedances	0	No of exceedances of ELV	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Daily average		Daily average ELV	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
	Monthly maximum	19.5	Daily average	17.7	17.5	17.6	17.2	17.4	17.7	17.6	17.7	17.5	17.7	17.4	18.0	18.1	18.3	18.5	18.2	18.0	17.8	18.1	18.4	18.3	Off	Off	18.0	17.8	17.9	19.0	19.5	19.3	18.7	17.8	
	No of invalid days	0	Value Valid?	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	
	Sum of exceedances	0	Value Exceeds ELV?	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	

Signed.....

Date.....

(Authorised to sign as a representative of the Operator)