


Permit Reference Number : PPC/A/1157446

Operator : Kanadevia Inova UK Operations Ltd

Installation: Earlsgate Energy Center

Form Number: Air A (A1)

### Reporting of Continuously Monitored Emissions to Air for CO2 % at Emission Point A1 For the month of October 2025



Monthly summary		Date	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24	25	26	27	28	29	30	31		
Half-hourly average		Half-hourly average ELV	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
	Monthly maximum	8.8	Maximum Half-hourly average	8.8	8.4	8.3	8.1	8.3	8.3	8.4	8.5	8.4	8.5	8.5	Off	Off	Off	8.4	8.5	8.0	8.5	8.3	8.1	8.1	8.1	8.2	8.2	8.2	8.3	8.2	8.2	8.3	8.5	8.2	
	Monthly mean	8.1	Mean Half-hourly average	8.2	8.2	8.0	8.0	8.1	8.2	8.2	8.3	8.3	8.3	8.0	Off	Off	Off	8.3	8.3	7.6	8.2	8.1	8.0	8.0	8.0	8.0	8.1	8.1	8.1	8.1	8.1	8.1	8.1	8.2	8.1
	Monthly minimum	6.2	Minimum Half-hourly average	8.0	8.1	7.9	7.9	8.0	8.0	8.1	8.1	8.2	8.2	6.2	Off	Off	Off	8.3	8.0	7.2	8.1	8.0	7.9	7.8	7.3	7.9	7.9	8.0	6.5	7.9	8.0	8.0	8.0	8.0	
	Total Invalid results	0	No of Invalid results	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
	Sum of exceedances	0	No of exceedances of ELV	N/A	Off	Off	Off	N/A																											
Daily average		Daily average ELV	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
	Monthly maximum	8.3	Daily average	8.2	8.2	8.0	8.0	8.1	8.2	8.2	8.3	8.3	8.3	8.0	Off	Off	Off	8.3	8.3	7.6	8.2	8.1	8.0	8.0	8.0	8.0	8.1	8.1	8.1	8.1	8.1	8.1	8.2	8.1	
	No of invalid days	0	Value Valid?	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	
	Sum of exceedances	0	Value Exceeds ELV?	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N

Signed.....

Date.....

(Authorised to sign as a representative of the Operator)


Permit Reference Number : PPC/A/1157446

Operator : Kanadevia Inova UK Operations Ltd

Installation: Earlsgate Energy Center

Form Number: Air B (A1)

**Reporting of Continuously Monitored Emissions to Air for Dry Oxygen % at Emission Point A1 For the month of October 2025**



Monthly summary		Date	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24	25	26	27	28	29	30	31		
Half-hourly average		Half-hourly average ELV	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
	Monthly maximum	13.9	Maximum Half-hourly average	6.9	6.7	6.9	6.7	7.5	7.0	6.6	6.8	7.0	13.9	Off	Off	Off	6.5	7.9	10.2	6.9	6.7	6.8	7.2	7.0	7.0	7.1	7.3	7.0	7.0	6.6	6.6	7.2	6.8		
	Monthly mean	6.4	Mean Half-hourly average	6.3	6.3	6.2	6.2	6.3	6.3	6.2	6.2	6.2	6.2	7.6	Off	Off	Off	6.3	6.6	9.0	6.4	6.3	6.3	6.3	6.3	6.3	6.3	6.6	6.4	6.3	6.3	6.0	6.1	6.1	
	Monthly minimum	5.0	Minimum Half-hourly average	5.6	5.8	5.5	5.7	5.7	5.8	5.6	5.6	5.8	5.6	5.3	Off	Off	Off	6.2	5.7	7.1	5.9	5.8	5.6	5.8	5.8	5.2	5.9	5.9	5.8	5.9	5.7	5.0	5.2	5.4	
	Total Invalid results	0	No of Invalid results	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
	Sum of exceedances	0	No of exceedances of ELV	N/A	N/A	Off	Off	Off	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A									
Daily average		Daily average ELV	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
	Monthly maximum	9.0	Daily average	6.3	6.3	6.2	6.2	6.3	6.3	6.2	6.2	6.2	6.2	7.6	Off	Off	Off	6.3	6.6	9.0	6.4	6.3	6.3	6.3	6.3	6.3	6.6	6.4	6.3	6.3	6.0	6.1	6.1		
	No of invalid days	0	Value Valid?	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y		
	Sum of exceedances	0	Value Exceeds ELV?	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	

Signed.....

Date.....

(Authorised to sign as a representative of the Operator)


Permit Reference Number : PPC/A/1157446

Operator : Kanadevia Inova UK Operations Ltd

Installation: Earlsgate Energy Center

Form Number: Air C (A1)

**Reporting of Continuously Monitored Emissions to Air for Moisture % at Emission Point A1 For the month of October 2025**




Monthly summary		Date	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24	25	26	27	28	29	30	31		
Half-hourly average		Half-hourly average ELV	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
	Monthly maximum	25.0	Maximum Half-hourly average	22.0	21.8	23.6	20.0	21.2	21.1	23.3	21.9	25.0	21.0	20.8	Off																				
	Monthly mean	18.1	Mean Half-hourly average	18.4	18.7	18.3	18.3	18.1	19.0	19.5	19.5	19.5	19.0	16.2	Off																				
	Monthly minimum	5.3	Minimum Half-hourly average	16.0	16.8	16.1	16.8	16.2	16.9	17.8	17.4	17.1	16.0	5.3	Off																				
	Total Invalid results	0	No of Invalid results	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
	Sum of exceedances	0	No of exceedances of ELV	N/A	N/A	Off																													
Daily average		Daily average ELV	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
	Monthly maximum	19.5	Daily average	18.4	18.7	18.3	18.3	18.1	19.0	19.5	19.5	19.5	19.0	16.2	Off																				
	No of invalid days	0	Value Valid?	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	
	Sum of exceedances	0	Value Exceeds ELV?	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N

Signed.....

Date.....

(Authorised to sign as a representative of the Operator)

### Reporting of Continuously Monitored Emissions to Air for CO mg/Nm3 at Emission Point A1 For the month of October 2025



Monthly summary		Date	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24	25	26	27	28	29	30	31		
10 Minute average		10 Minute average ELV (95th Percentile)	150	150	150	150	150	150	150	150	150	150	150	150	150	150	150	150	150	150	150	150	150	150	150	150	150	150	150	150	150	150	150		
	Monthly Maximum 10-min	990	Maximum 10 Minute average	402	101	231	183	517	320	355	104	15	18	620	Off	Off	Off	3	990	7	351	43	21	118	960	542	36	87	19	124	144	71	280	400	
	Monthly mean 10-min avgs	9	95th Percentile	7	6	14	9	9	7	8	12	8	8	193	Off	Off	Off	1	11	0	10	7	13	44	20	14	12	12	9	9	14	15	16	12	
	Monthly Minimum 10-min	0	Minimum 10 Minute average	0	0	2	2	1	1	2	1	1	1	1	Off	Off	Off	1	0	0	1	0	2	4	3	1	3	2	2	1	4	4	3	2	
	Total Invalid results	2	No of Invalid results	0	0	0	0	0	0	0	0	0	0	1	0	0	0	0	0	0	0	0	0	0	0	0	0	0	1	0	0	0	0	0	0
			Number of results above 150mg/m³	2	0	1	1	2	2	1	0	0	0	10	Off	Off	Off	0	3	0	2	0	0	0	1	2	0	0	0	0	0	0	1	1	
		Sum of Exceedances of 95th percentile ELV	1	95th Percentile ELV Exceeded (Y/N)																															
Daily average		Daily average ELV	50	50	50	50	50	50	50	50	50	50	50	50	50	50	50	50	50	50	50	50	50	50	50	50	50	50	50	50	50	50	50	50	
	Monthly maximum	33	Daily average	8	4	8	7	10	9	7	5	4	4	33	Off	Off	Off	1	12	2	10	4	6	13	15	13	8	9	6	6	10	7	10	11	
	No of invalid days	0	Value Valid?	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	
	Sum of exceedances	0	Value Exceeds ELV? (Y/N)	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N

Signed.....

Date.....

(Authorised to sign as a representative of the Operator)

Environment Agency explanatory note: The 10-minute average ELV is based on the "95th percentile" In this case this means that 95% of the 10 minute averages in the calendar day (= 137) must be below 150 mg/m3, and 5% (= 7) are allowed to be any value above 150 mg/m3. Whilst we expect operators to minimise CO emissions at all times, it is perfectly acceptable for the value of the maximum 10-minute average to be above 150 mg/m3, provided the 95th percentile ELV has been met for that period

Permit Reference Number : PPC/A/1157446


Operator : Kanadevia Inova UK Operations Ltd

Installation: Earlsgate Energy Center

Form Number: Air 3 (A1)

**Reporting of Continuously Monitored Emissions to Air for HCl mg/Nm3 at Emission Point A1 For the month of October 2025**

Daily and Half-hourly Average Monitoring Data



Monthly summary		Date	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24	25	26	27	28	29	30	31			
Half-hourly average		Half-hourly average ELV	60.0	60.0	60.0	60.0	60.0	60.0	60.0	60.0	60.0	60.0	60.0	60.0	60.0	60.0	60.0	60.0	60.0	60.0	60.0	60.0	60.0	60.0	60.0	60.0	60.0	60.0	60.0	60.0	60.0	60.0	60.0			
	Monthly maximum	9.9	Maximum Half-hourly average	6.8	6.7	7.1	6.9	6.7	7.3	5.8	7.4	7.5	6.8	9.9	Off	Off	Off	3.8	3.6	2.1	2.7	5.0	7.8	4.0	6.1	7.4	7.4	7.1	7.0	7.4	7.3	7.5	9.0	7.4		
	Monthly mean	4.8	Mean Half-hourly average	5.4	4.8	5.2	4.5	5.0	6.4	4.7	5.7	5.4	5.4	6.4	Off	Off	Off	3.6	2.9	2.1	2.1	2.8	3.7	3.1	4.0	5.7	5.5	6.0	5.1	6.1	6.6	6.4	5.5	5.7		
	Monthly minimum	1.4	Minimum Half-hourly average	3.8	2.9	3.2	2.8	3.5	4.8	3.2	3.6	3.8	3.8	4.0	Off	Off	Off	3.3	2.0	2.0	1.4	1.6	2.4	2.5	2.9	4.2	3.6	4.9	3.4	5.3	5.2	5.2	3.4	3.8		
	Total Invalid results	0	No of Invalid results	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
	Sum of exceedances	0	No of exceedances of ELV	0	0	0	0	0	0	0	0	0	0	0	0	Off	Off	Off	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	
Daily average		Daily average ELV	8.0	8.0	8.0	8.0	8.0	8.0	8.0	8.0	8.0	8.0	8.0	8.0	8.0	8.0	8.0	8.0	8.0	8.0	8.0	8.0	8.0	8.0	8.0	8.0	8.0	8.0	8.0	8.0	8.0	8.0	8.0	8.0		
	Monthly maximum	6.6	Daily average	5.4	4.8	5.2	4.5	5.0	6.4	4.7	5.7	5.4	5.4	6.4	Off	Off	Off	3.6	2.9	2.1	2.1	2.8	3.7	3.1	4.0	5.7	5.5	6.0	5.1	6.1	6.6	6.4	5.5	5.7		
	No of invalid days	0	Value Valid?	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y		
	Sum of exceedances	0	Value Exceeds ELV?	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	

Signed.....

Date.....

(Authorised to sign as a representative of the Operator)

Permit Reference Number : PPC/A/1157446


Operator : Kanadevia Inova UK Operations Ltd

Installation: Earlsgate Energy Center

Form Number: Air 5 (A1)

**Reporting of Continuously Monitored Emissions to Air for SO2 mg/Nm3 at Emission Point A1 For the month of October 2025**

Daily and Half-hourly Average Monitoring Data



Monthly summary		Date	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24	25	26	27	28	29	30	31		
Half-hourly average		Half-hourly average ELV	200	200	200	200	200	200	200	200	200	200	200	200	200	200	200	200	200	200	200	200	200	200	200	200	200	200	200	200	200	200	200		
	Monthly maximum	187	Maximum Half-hourly average	21	20	13	23	9	10	12	5	15	6	187	Off	Off	Off	32	42	26	50	37	35	10	15	19	10	20	23	7	7	8	18	9	
	Monthly mean	10	Mean Half-hourly average	11	7	7	10	5	5	6	5	6	4	21	Off	Off	Off	30	21	24	23	15	13	6	6	8	6	8	8	6	6	6	6	6	
	Monthly minimum	1	Minimum Half-hourly average	5	4	5	5	3	4	4	4	4	4	3	Off	Off	Off	29	7	21	5	4	5	5	1	5	5	4	5	5	5	5	4	5	
	Total Invalid results	0	No of Invalid results	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
	Sum of exceedances	0	No of exceedances of ELV	0	0	0	0	0	0	0	0	0	0	0	Off	Off	Off	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
Daily average		Daily average ELV	40	40	40	40	40	40	40	40	40	40	40	40	40	40	40	40	40	40	40	40	40	40	40	40	40	40	40	40	40	40	40		
	Monthly maximum	30	Daily average	11	7	7	10	5	5	6	5	6	4	21	Off	Off	Off	30	21	24	23	15	13	6	6	8	6	8	8	6	6	6	6	6	
	No of invalid days	0	Value Valid?	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	
	Sum of exceedances	0	Value Exceeds ELV?	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	

Signed.....

Date.....

(Authorised to sign as a representative of the Operator)

Permit Reference Number : PPC/A/1157446


Operator : Kanadevia Inova UK Operations Ltd

Installation: Earlsgate Energy Center

Form Number: Air 6 (A1)

### Reporting of Continuously Monitored Emissions to Air for NOx mg/Nm3 at Emission Point A1 For the month of October 2025

Daily and Half-hourly Average Monitoring Data



Monthly summary		Date	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24	25	26	27	28	29	30	31		
Half-hourly average		Half-hourly average ELV	400	400	400	400	400	400	400	400	400	400	400	400	400	400	400	400	400	400	400	400	400	400	400	400	400	400	400	400	400	400	400	400	
	Monthly maximum	182	Maximum Half-hourly average	182	175	163	170	166	166	163	162	162	162	167	Off	Off	Off	158	176	142	160	161	163	170	165	172	170	166	162	172	159	160	163	161	
	Monthly mean	151	Mean Half-hourly average	154	157	149	153	151	153	152	151	152	152	146	Off	Off	Off	155	153	124	150	152	152	151	153	153	153	151	152	152	152	152	152	152	
	Monthly minimum	90	Minimum Half-hourly average	128	139	119	137	137	141	131	129	143	141	90	Off	Off	Off	152	138	98	112	137	141	98	121	133	143	110	138	132	142	137	142	140	
	Total Invalid results	0	No of Invalid results	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
	Sum of exceedances	0	No of exceedances of ELV	0	0	0	0	0	0	0	0	0	0	0	0	Off	Off	Off	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
Daily average		Daily average ELV	180	180	180	180	180	180	180	180	180	180	180	180	180	180	180	180	180	180	180	180	180	180	180	180	180	180	180	180	180	180	180	180	
	Monthly maximum	157	Daily average	154	157	149	153	151	153	152	151	152	152	146	Off	Off	Off	155	153	124	150	152	152	151	153	153	153	151	152	152	152	152	152	152	
	No of invalid days	0	Value Valid?	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	
	Sum of exceedances	0	Value Exceeds ELV?	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N

Signed.....

Date.....

(Authorised to sign as a representative of the Operator)


Permit Reference Number : PPC/A/1157446

Operator : Kanadevia Inova UK Operations Ltd

Installation: Earlsgate Energy Center

Form Number: Air 2 (A1)

### Reporting of Continuously Monitored Emissions to Air for TOC mg/Nm3 at Emission Point A1 For the month of October 2025



Monthly summary		Date	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24	25	26	27	28	29	30	31		
Half-hourly average		Half-hourly average ELV	20.0	20.0	20.0	20.0	20.0	20.0	20.0	20.0	20.0	20.0	20.0	20.0	20.0	20.0	20.0	20.0	20.0	20.0	20.0	20.0	20.0	20.0	20.0	20.0	20.0	20.0	20.0	20.0	20.0	20.0	20.0		
	Monthly maximum	117.7	Maximum Half-hourly average	5.6	4.8	4.9	5.7	5.2	4.1	12.0	4.1	5.0	4.2	117.7	Off	Off	Off	2.8	11.3	2.9	5.9	4.5	7.6	6.2	21.8	6.4	5.5	6.1	5.7	5.3	5.9	4.6	9.5	5.6	
	Monthly mean	3.6	Mean Half-hourly average	2.4	2.9	3.3	3.9	3.9	3.0	3.2	2.9	3.3	2.9	6.7	Off	Off	Off	2.3	2.2	2.3	4.0	3.2	4.1	5.3	4.9	4.0	4.4	4.8	1.7	3.1	4.2	3.8	4.2	4.4	
	Monthly minimum	0.0	Minimum Half-hourly average	0.3	1.1	2.2	3.0	2.5	2.4	2.2	1.8	2.2	2.0	1.7	Off	Off	Off	2.0	1.3	1.3	2.8	1.4	2.5	4.1	2.8	1.0	3.1	2.1	0.0	0.0	3.0	2.6	3.0	2.5	
	Total Invalid results	0	No of Invalid results	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
	Sum of exceedances	3	No of exceedances of ELV	0	0	0	0	0	0	0	0	0	0	0	2	Off	Off	Off	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
Daily average		Daily average ELV	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0		
	Monthly maximum	6.7	Daily average	2.4	2.9	3.3	3.9	3.9	3.0	3.2	2.9	3.3	2.9	6.7	Off	Off	Off	2.3	2.2	2.3	4.0	3.2	4.1	5.3	4.9	4.0	4.4	4.8	1.7	3.1	4.2	3.8	4.2	4.4	
	No of invalid days	0	Value Valid?	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	
	Sum of exceedances	0	Value Exceeds ELV?	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N

Signed.....

Date.....

(Authorised to sign as a representative of the Operator)


Permit Reference Number : PPC/A/1157446

Operator : Kanadevia Inova UK Operations Ltd

Installation: Earlsgate Energy Center

Form Number: Air 7 (A1)

### Reporting of Continuously Monitored Emissions to Air for NH3 mg/Nm3 at Emission Point A1 For the month of October 2025



Monthly summary		Date	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24	25	26	27	28	29	30	31		
Half-hourly average		Half-hourly average ELV	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
	Monthly maximum	16.5	Maximum Half-hourly average	0.3	0.1	0.2	0.0	0.2	0.2	0.8	0.1	0.2	0.1	16.5	Off	Off	Off	1.2	0.5	0.3	2.2	0.2	0.1	0.4	0.6	0.3	0.2	0.2	0.2	0.1	0.1	0.2	0.3	0.1	
	Monthly mean	0.2	Mean Half-hourly average	0.1	0.0	0.1	0.0	0.0	0.1	0.2	0.0	0.0	0.0	1.8	Off	Off	Off	0.9	0.4	0.3	0.3	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.0	0.1	0.1	0.1	0.0	
	Monthly minimum	0.0	Minimum Half-hourly average	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	Off	Off	Off	0.6	0.2	0.3	0.1	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	
	Total Invalid results	0	No of Invalid results	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
	Sum of exceedances	0	No of exceedances of ELV	N/A	Off	Off	Off	N/A	N/A																										
Daily average		Daily average ELV	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	
	Monthly maximum	1.8	Daily average	0.1	0.0	0.1	0.0	0.0	0.1	0.2	0.0	0.0	0.0	1.8	Off	Off	Off	0.9	0.4	0.3	0.3	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.0	0.1	0.1	0.1	0.0	
	No of invalid days	0	Value Valid?	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	
	Sum of exceedances	0	Value Exceeds ELV?	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N

Signed.....

Date.....

(Authorised to sign as a representative of the Operator)

Permit Reference Number : PPC/A/1157446


Operator : Kanadevia Inova UK Operations Ltd

Installation: Earlsgate Energy Center

Form Number: Air 1 (A1)

**Reporting of Continuously Monitored Emissions to Air for Particulates mg/Nm3 at Emission Point A1 For the month of October 2025**

Daily and Half-hourly Average Monitoring Data



Monthly summary		Date	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24	25	26	27	28	29	30	31	
Half-hourly average		Half-hourly average ELV	30.0	30.0	30.0	30.0	30.0	30.0	30.0	30.0	30.0	30.0	30.0	30.0	30.0	30.0	30.0	30.0	30.0	30.0	30.0	30.0	30.0	30.0	30.0	30.0	30.0	30.0	30.0	30.0	30.0	30.0	30.0	
	Monthly maximum	0.4	Maximum Half-hourly average	0.1	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.4	Off	Off	Off	0.1	0.4	0.2	0.3	0.4	0.4	0.3	0.2	0.2	0.2	0.1	0.2	0.1	0.2	0.2	0.2	
	Monthly mean	0.1	Mean Half-hourly average	0.1	0.1	0.2	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.2	Off	Off	Off	0.1	0.2	0.2	0.2	0.3	0.2	0.2	0.2	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	
	Monthly minimum	0.1	Minimum Half-hourly average	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	Off	Off	Off	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	
	Total Invalid results	0	No of Invalid results	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
	Sum of exceedances	0	No of exceedances of ELV	0	0	0	0	0	0	0	0	0	0	0	Off	Off	Off	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
Daily average		Daily average ELV	5.0	5.0	5.0	5.0	5.0	5.0	5.0	5.0	5.0	5.0	5.0	5.0	5.0	5.0	5.0	5.0	5.0	5.0	5.0	5.0	5.0	5.0	5.0	5.0	5.0	5.0	5.0	5.0	5.0	5.0	5.0	
	Monthly maximum	0.3	Daily average	0.1	0.1	0.2	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.2	Off	Off	Off	0.1	0.2	0.2	0.2	0.3	0.2	0.2	0.2	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	
	No of invalid days	0	Value Valid?	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	
	Sum of exceedances	0	Value Exceeds ELV?	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N

Signed.....

Date.....

(Authorised to sign as a representative of the Operator)


Permit Reference Number : PPC/A/1157446

Operator : Kanadevia Inova UK Operations Ltd

Installation: Earlsgate Energy Center

Form Number: Air 8 (A1)

### Reporting of Continuously Monitored Emissions to Air for N2O mg/Nm3 at Emission Point A1 For the month of October 2025



Monthly summary		Date	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24	25	26	27	28	29	30	31		
Half-hourly average		Half-hourly average ELV	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
	Monthly maximum	15.0	Maximum Half-hourly average	5.0	1.9	2.8	2.8	5.7	3.0	5.3	3.9	4.4	4.4	15.0	Off	Off	Off	3.3	5.8	5.1	5.4	4.6	4.9	6.0	5.8	6.3	5.6	7.2	5.0	4.4	4.9	4.8	4.9	4.9	
	Monthly mean	2.6	Mean Half-hourly average	1.4	0.7	1.4	1.5	1.3	1.4	1.7	1.6	2.1	1.7	3.6	Off	Off	Off	2.6	3.3	2.8	2.9	2.9	3.2	2.9	3.4	3.6	3.5	3.9	3.4	2.9	3.2	3.0	2.7	3.1	
	Monthly minimum	0.2	Minimum Half-hourly average	0.2	0.2	0.2	0.8	0.2	0.4	0.6	0.5	0.8	0.4	0.4	Off	Off	Off	2.0	1.7	1.5	1.4	1.6	1.7	0.8	2.0	1.4	2.4	1.5	1.5	1.4	2.0	0.8	0.8	1.6	
	Total Invalid results	0	No of Invalid results	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
	Sum of exceedances	0	No of exceedances of ELV	N/A	Off	Off	Off	N/A																											
Daily average		Daily average ELV	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	Monthly maximum	3.9	Daily average	1.4	0.7	1.4	1.5	1.3	1.4	1.7	1.6	2.1	1.7	3.6	Off	Off	Off	2.6	3.3	2.8	2.9	2.9	3.2	2.9	3.4	3.6	3.5	3.9	3.4	2.9	3.2	3.0	2.7	3.1	
	No of invalid days	0	Value Valid?	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y
	Sum of exceedances	0	Value Exceeds ELV?	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N

Signed.....

Date.....

(Authorised to sign as a representative of the Operator)