
Permit Reference Number : PPC/A/1157446 Operator : Kanadevia Inova UK Operations Ltd

Installation: Earlsgate Energy Center Form Number: Air 3 (A1)

Reporting of Continuously Monitored Emissions to Air for HCl mg/Nm3 at Emission Point A1 For the month of July 2026



	Monthly summary		Date	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24	25	26	27	28	29	30	31
			Half-hourly average ELV	60.0	60.0	60.0	60.0	60.0	60.0	60.0	60.0	60.0	60.0	60.0	60.0	60.0	60.0	60.0	60.0	60.0	60.0	60.0	60.0	60.0	60.0	60.0	60.0	60.0	60.0	60.0	60.0	60.0	60.0	60.0
	Monthly maximum	8.6	Maximum Half-hourly average	7.7	7.6	7.3	7.9	7.0	7.3	7.3	7.3	7.3	7.2	7.2	8.6	6.5	7.2	6.3	4.2	3.6	4.9	6.0	4.0	5.0	7.0	7.3	7.3	7.2	7.3	7.3	7.2	7.2	7.3	7.2
Half-hourly	Monthly mean	5.3	Mean Half-hourly average	6.5	5.7	6.4	5.3	5.6	6.4	6.5	6.3	6.1	5.4	6.2	5.3	5.2	5.6	3.5	2.8	2.7	2.9	3.2	3.1	3.3	4.5	6.2	6.5	5.7	6.2	6.4	6.3	6.4	5.7	5.5
average	Monthly minimum	2.3	Minimum Half-hourly average	5.5	4.5	5.0	2.5	4.7	5.5	5.3	5.1	5.1	4.3	5.0	3.5	4.2	3.8	2.5	2.3	2.3	2.4	2.5	2.4	2.4	2.9	4.4	5.4	4.4	4.7	5.3	5.1	5.5	4.6	4.5
	Total Invalid results	0	No of Invalid results	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
	Sum of exceedances	0	No of exceedances of ELV	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
			Daily average ELV	8.0	8.0	8.0	8.0	8.0	8.0	8.0	8.0	8.0	8.0	8.0	8.0	8.0	8.0	8.0	8.0	8.0	8.0	8.0	8.0	8.0	8.0	8.0	8.0	8.0	8.0	8.0	8.0	8.0	8.0	8.0
Daily	Monthly maximum	6.5	Daily average	6.5	5.7	6.4	5.3	5.6	6.4	6.5	6.3	6.1	5.4	6.2	5.3	5.2	5.6	3.5	2.8	2.7	2.9	3.2	3.1	3.3	4.5	6.2	6.5	5.7	6.2	6.4	6.3	6.4	5.7	5.5
average	No of invalid days	0	Value Valid?	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y
	Sum of exceedances	0	Value Exceeds ELV?	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N


Signed..... Date.....

(Authorised to sign as a representative of the Operator)

Permit Reference Number : PPC/A/1157446 Operator : Kanadevia Inova UK Operations Ltd

Installation: Earlsgate Energy Center Form Number: Air 5 (A1)

Reporting of Continuously Monitored Emissions to Air for SO2 mg/Nm3 at Emission Point A1 For the month of July 2026



	Monthly summary		Date	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24	25	26	27	28	29	30	31
			Half-hourly average ELV	200	200	200	200	200	200	200	200	200	200	200	200	200	200	200	200	200	200	200	200	200	200	200	200	200	200	200	200	200	200	200
Half-hourly average	Monthly maximum	27	Maximum Half-hourly average	8	8	7	15	9	7	7	8	8	8	7	18	6	6	24	15	15	27	26	10	11	11	8	9	10	8	9	8	9	8	9
	Monthly mean	6	Mean Half-hourly average	6	6	6	7	6	6	6	6	6	6	5	4	3	5	7	7	7	9	8	6	7	7	6	7	7	7	7	7	7	7	7
	Monthly minimum	1	Minimum Half-hourly average	3	4	5	4	5	5	5	5	5	2	2	1	2	2	5	4	5	6	5	4	4	5	5	6	6	3	5	5	6	5	5
	Total Invalid results	0	No of Invalid results	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
	Sum of exceedances	0	No of exceedances of ELV	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
			Daily average ELV	40	40	40	40	40	40	40	40	40	40	40	40	40	40	40	40	40	40	40	40	40	40	40	40	40	40	40	40	40	40	40
Daily average	Monthly maximum	9	Daily average	6	6	6	7	6	6	6	6	6	6	5	4	3	5	7	7	7	9	8	6	7	7	6	7	7	7	7	7	7	7	7
	No of invalid days	0	Value Valid?	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y
	Sum of exceedances	0	Value Exceeds ELV?	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N


Signed..... Date.....

(Authorised to sign as a representative of the Operator)

Permit Reference Number : PPC/A/1157446 Operator : Kanadevia Inova UK Operations Ltd

Installation: Earlsgate Energy Center Form Number: Air 6 (A1)

Reporting of Continuously Monitored Emissions to Air for NOx mg/Nm3 at Emission Point A1 For the month of July 2026



	Monthly summary		Date	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24	25	26	27	28	29	30	31
			Half-hourly average ELV	400	400	400	400	400	400	400	400	400	400	400	400	400	400	400	400	400	400	400	400	400	400	400	400	400	400	400	400	400	400	400
	Monthly maximum	199	Maximum Half-hourly average	171	173	169	177	163	184	166	186	170	179	171	177	184	166	167	170	167	174	158	173	189	183	199	175	167	174	163	173	169	176	189
Half-hourly	Monthly mean	152	Mean Half-hourly average	152	152	152	152	152	152	152	153	151	152	152	152	152	152	152	152	153	154	151	153	153	152	154	152	153	152	151	152	153	152	155
average	Monthly minimum	116	Minimum Half-hourly average	136	131	125	120	143	123	138	132	131	121	134	133	138	142	132	116	139	134	140	139	131	136	124	131	135	139	124	130	127	138	123
	Total Invalid results	0	No of Invalid results	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
	Sum of exceedances	0	No of exceedances of ELV	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
			Daily average ELV	180	180	180	180	180	180	180	180	180	180	180	180	180	180	180	180	180	180	180	180	180	180	180	180	180	180	180	180	180	180	180
Daily	Monthly maximum	155	Daily average	152	152	152	152	152	152	152	153	151	152	152	152	152	152	152	152	153	154	151	153	153	152	154	152	153	152	151	152	153	152	155
average	No of invalid days	0	Value Valid?	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y
	Sum of exceedances	0	Value Exceeds ELV?	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N


Signed..... Date.....

(Authorised to sign as a representative of the Operator)

Permit Reference Number : PPC/A/1157446 Operator : Kanadevia Inova UK Operations Ltd

Installation: Earlsgate Energy Center Form Number: Air 2 (A1)

Reporting of Continuously Monitored Emissions to Air for TOC mg/Nm3 at Emission Point A1 For the month of July 2026



	Monthly summary		Date	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24	25	26	27	28	29	30	31
			Half-hourly average ELV	20.0	20.0	20.0	20.0	20.0	20.0	20.0	20.0	20.0	20.0	20.0	20.0	20.0	20.0	20.0	20.0	20.0	20.0	20.0	20.0	20.0	20.0	20.0	20.0	20.0	20.0	20.0	20.0	20.0	20.0	20.0
	Monthly maximum	145.8	Maximum Half-hourly average	3.4	4.2	5.5	145.8	5.4	5.4	5.5	7.5	6.5	8.9	8.9	12.2	9.9	11.5	5.7	5.0	5.1	5.5	6.7	6.1	6.0	7.5	5.9	5.6	5.7	5.2	6.2	5.5	4.9	5.3	4.6
Half-hourly	Monthly mean	4.7	Mean Half-hourly average	2.7	3.0	4.0	8.3	4.4	4.4	4.0	5.1	4.2	5.4	6.4	7.5	7.3	6.9	4.2	4.2	4.3	4.6	5.1	4.9	5.0	3.8	4.2	3.8	4.6	4.5	4.7	4.2	3.9	3.7	3.1
average	Monthly minimum	0.9	Minimum Half-hourly average	1.6	1.6	3.0	2.6	3.3	3.0	2.3	3.1	0.9	0.9	4.9	4.3	5.4	3.5	3.0	3.2	2.7	3.7	4.0	3.7	4.0	0.9	1.0	0.9	3.4	3.5	3.6	3.0	2.5	2.1	0.9
	Total Invalid results	0	No of Invalid results	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
	Sum of exceedances	2	No of exceedances of ELV	0	0	0	2	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
			Daily average ELV	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0
Daily	Monthly maximum	8.3	Daily average	2.7	3.0	4.0	8.3	4.4	4.4	4.0	5.1	4.2	5.4	6.4	7.5	7.3	6.9	4.2	4.2	4.3	4.6	5.1	4.9	5.0	3.8	4.2	3.8	4.6	4.5	4.7	4.2	3.9	3.7	3.1
average	No of invalid days	0	Value Valid?	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y
	Sum of exceedances	0	Value Exceeds ELV?	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N


Signed..... Date.....

(Authorised to sign as a representative of the Operator)

Permit Reference Number : PPC/A/1157446 Operator : Kanadevia Inova UK Operations Ltd

Installation: Earlsgate Energy Center Form Number: Air 7 (A1)

Reporting of Continuously Monitored Emissions to Air for NH3 mg/Nm3 at Emission Point A1 For the month of July 2026



	Monthly summary		Date	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24	25	26	27	28	29	30	31
Half-hourly average			Half-hourly average ELV	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	Monthly maximum	2.4	Maximum Half-hourly average	0.4	0.4	0.3	2.4	0.6	0.3	0.4	0.5	0.3	0.4	0.4	0.4	0.3	0.3	0.5	0.4	0.4	0.3	0.2	0.3	0.3	0.3	0.3	0.3	0.3	0.4	0.3	0.4	0.4	0.5	0.5
	Monthly mean	0.2	Mean Half-hourly average	0.2	0.2	0.2	0.8	0.3	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.1	0.3	0.3	0.2	0.2	0.1	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.3	0.2	0.3	0.3
	Monthly minimum	0.0	Minimum Half-hourly average	0.1	0.1	0.1	0.1	0.2	0.1	0.1	0.1	0.1	0.1	0.0	0.0	0.0	0.0	0.2	0.2	0.1	0.1	0.0	0.1	0.1	0.1	0.1	0.1	0.1	0.2	0.1	0.1	0.2	0.2	0.2
	Total Invalid results	0	No of Invalid results	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
	Sum of exceedances	0	No of exceedances of ELV	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Daily average			Daily average ELV	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0
	Monthly maximum	0.8	Daily average	0.2	0.2	0.2	0.8	0.3	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.1	0.3	0.3	0.2	0.2	0.1	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.3	0.2	0.3	0.3
	No of invalid days	0	Value Valid?	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y
	Sum of exceedances	0	Value Exceeds ELV?	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N


Signed..... Date.....

(Authorised to sign as a representative of the Operator)

Permit Reference Number : PPC/A/1157446 Operator : Kanadevia Inova UK Operations Ltd

Installation: Earlsgate Energy Center Form Number: Air 1 (A1)

Reporting of Continuously Monitored Emissions to Air for Particulates mg/Nm3 at Emission Point A1 For the month of July 2026



	Monthly summary		Date	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24	25	26	27	28	29	30	31
			Half-hourly average ELV	30.0	30.0	30.0	30.0	30.0	30.0	30.0	30.0	30.0	30.0	30.0	30.0	30.0	30.0	30.0	30.0	30.0	30.0	30.0	30.0	30.0	30.0	30.0	30.0	30.0	30.0	30.0	30.0	30.0	30.0	30.0
	Monthly maximum	0.2	Maximum Half-hourly average	0.1	0.1	0.1	0.2	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.2	0.1	0.2	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1
Half-hourly	Monthly mean	0.1	Mean Half-hourly average	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1
average	Monthly minimum	0.1	Minimum Half-hourly average	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1
	Total Invalid results	0	No of Invalid results	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
	Sum of exceedances	0	No of exceedances of ELV	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
			Daily average ELV	5.0	5.0	5.0	5.0	5.0	5.0	5.0	5.0	5.0	5.0	5.0	5.0	5.0	5.0	5.0	5.0	5.0	5.0	5.0	5.0	5.0	5.0	5.0	5.0	5.0	5.0	5.0	5.0	5.0	5.0	5.0
Daily	Monthly maximum	0.1	Daily average	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1
average	No of invalid days	0	Value Valid?	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y
	Sum of exceedances	0	Value Exceeds ELV?	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N


Signed..... Date.....

(Authorised to sign as a representative of the Operator)

Permit Reference Number : PPC/A/1157446 Operator : Kanadevia Inova UK Operations Ltd

Installation: Earlsgate Energy Center Form Number: Air 8 (A1)

Reporting of Continuously Monitored Emissions to Air for N2O mg/Nm3 at Emission Point A1 For the month of July 2026



	Monthly summary		Date	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24	25	26	27	28	29	30	31
			Half-hourly average ELV	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	Monthly maximum	21.8	Maximum Half-hourly average	4.8	6.0	5.1	21.8	4.6	4.6	5.6	4.1	5.2	4.5	3.7	3.6	3.5	3.2	4.7	4.5	4.9	5.6	4.0	5.6	4.2	3.7	3.8	4.0	5.7	4.0	3.9	5.2	5.5	3.5	4.4
Half-hourly	Monthly mean	2.6	Mean Half-hourly average	2.9	3.2	2.6	4.0	2.4	2.3	2.6	2.5	2.5	2.2	2.2	1.9	2.1	2.1	2.5	2.4	2.6	2.7	2.2	2.4	2.2	2.5	2.5	2.6	3.0	3.0	2.6	2.9	2.7	2.6	2.2
average	Monthly minimum	0.3	Minimum Half-hourly average	1.3	1.7	1.0	0.8	1.5	0.6	1.6	0.9	1.2	0.6	0.8	0.3	0.3	1.4	1.3	1.4	1.2	1.7	1.1	1.3	1.4	1.3	1.2	1.4	1.6	1.5	1.6	1.1	1.1	1.3	0.9
	Total Invalid results	0	No of Invalid results	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
	Sum of exceedances	0	No of exceedances of ELV	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
			Daily average ELV	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Daily	Monthly maximum	4.0	Daily average	2.9	3.2	2.6	4.0	2.4	2.3	2.6	2.5	2.5	2.2	2.2	1.9	2.1	2.1	2.5	2.4	2.6	2.7	2.2	2.4	2.2	2.5	2.5	2.6	3.0	3.0	2.6	2.9	2.7	2.6	2.2
average	No of invalid days	0	Value Valid?	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y
	Sum of exceedances	0	Value Exceeds ELV?	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N


Signed..... Date.....

(Authorised to sign as a representative of the Operator)

Permit Reference Number : PPC/A/1157446 Operator : Kanadevia Inova UK Operations Ltd

Installation: Earlsgate Energy Center Form Number: Air 4 (A1)

Reporting of Continuously Monitored Emissions to Air for CO mg/Nm3 at Emission Point A1 For the month of July 2026



	Monthly summary		Date	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24	25	26	27	28	29	30	31
10 Minute average			10 Minute average ELV (95th Percentile)	150	150	150	150	150	150	150	150	150	150	150	150	150	150	150	150	150	150	150	150	150	150	150	150	150	150	150	150	150	150	150
	Monthly Maximum 10-min	1559	Maximum 10 Minute average	133	309	232	1559	202	64	77	533	100	277	18	148	54	165	130	74	111	62	61	86	119	12	12	89	58	106	49	528	188	29	68
	Monthly mean 10-min avgs	9	95th Percentile	7	6	9	96	14	8	10	11	13	16	14	22	19	22	45	8	10	8	9	8	10	8	8	8	15	9	8	10	13	8	7
	Monthly Minimum 10-min	0	Minimum 10 Minute average	1	1	2	2	3	3	2	1	0	0	5	3	5	3	2	3	3	2	3	3	3	0	0	0	2	3	3	2	2	1	0
	Total Invalid results	3	No of Invalid results	0	0	0	2	0	0	0	0	0	0	0	1	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
			Number of results above 150mg/m³	0	1	1	6	1	0	0	1	0	1	0	0	0	1	0	0	0	0	0	0	0	0	0	0	0	0	0	1	1	0	0
	Sum of Exceedances of 95th percentile ELV	0	95th Percentile ELV Exceeded (Y/N)	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N
Daily average			Daily average ELV	50	50	50	50	50	50	50	50	50	50	50	50	50	50	50	50	50	50	50	50	50	50	50	50	50	50	50	50	50	50	50
	Monthly maximum	39	Daily average	5	6	8	39	8	6	6	12	7	11	9	13	12	13	11	6	7	7	7	6	8	4	5	6	7	6	6	11	8	5	4
	No of invalid days	0	Value Valid?	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y
	Sum of exceedances	0	Value Exceeds ELV? (Y/N)	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N

Signed..... Date.....


(Authorised to sign as a representative of the Operator)

Environment Agency explanatory note: The 10-minute average ELV is based on the "95th percentile" In this case this means that 95% of the 10 minute averages in the calendar day (= 137) must be below 150 mg/m3, and 5% (= 7) are allowed to be any value above 150 mg/m3. Whilst we expect operators to minimise CO emissions at all times, it is perfectly acceptable for the value of the maximum 10-minute average to be above 150 mg/m3, provided the 95th percentile ELV has been met for that period

Permit Reference Number : PPC/A/1157446 Operator : Kanadevia Inova UK Operations Ltd

Installation: Earlsgate Energy Center Form Number: Air A (A1)

Reporting of Continuously Monitored Emissions to Air for CO2 % at Emission Point A1 For the month of July 2026



	Monthly summary		Date	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24	25	26	27	28	29	30	31
			Half-hourly average ELV	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	Monthly maximum	8.8	Maximum Half-hourly average	8.7	8.4	8.3	8.4	8.3	8.2	8.2	8.4	8.3	8.3	8.4	8.8	8.6	8.4	8.4	8.5	8.3	8.3	8.3	8.3	8.3	8.3	8.3	8.2	8.1	8.1	8.1	8.2	8.2	8.2	8.3
Half-hourly	Monthly mean	8.2	Mean Half-hourly average	8.3	8.2	8.2	8.2	8.2	8.1	8.2	8.2	8.2	8.2	8.2	8.5	8.3	8.2	8.2	8.2	8.2	8.2	8.2	8.2	8.2	8.2	8.1	8.1	8.0	8.0	8.1	8.1	8.1	8.1	8.1
average	Monthly minimum	7.3	Minimum Half-hourly average	8.1	8.1	8.1	7.3	8.1	8.0	8.1	8.1	8.1	8.1	8.1	8.3	8.2	8.1	8.1	8.1	8.0	8.1	8.1	8.2	8.1	8.0	8.0	8.0	7.9	7.8	8.0	8.0	8.0	8.0	8.1
	Total Invalid results	0	No of Invalid results	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
	Sum of exceedances	0	No of exceedances of ELV	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
			Daily average ELV	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Daily	Monthly maximum	8.5	Daily average	8.3	8.2	8.2	8.2	8.2	8.1	8.2	8.2	8.2	8.2	8.2	8.5	8.3	8.2	8.2	8.2	8.2	8.2	8.2	8.2	8.2	8.2	8.1	8.1	8.0	8.0	8.1	8.1	8.1	8.1	8.1
average	No of invalid days	0	Value Valid?	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y
	Sum of exceedances	0	Value Exceeds ELV?	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N


Signed..... Date.....

(Authorised to sign as a representative of the Operator)

Permit Reference Number : PPC/A/1157446 Operator : Kanadevia Inova UK Operations Ltd

Installation: Earlsgate Energy Center Form Number: Air B (A1)

Reporting of Continuously Monitored Emissions to Air for Dry Oxygen % at Emission Point A1 For the month of July 2026



	Monthly summary		Date	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24	25	26	27	28	29	30	31
			Half-hourly average ELV	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	Monthly maximum	10.0	Maximum Half-hourly average	7.3	7.4	7.4	10.0	7.5	7.1	7.3	7.3	7.5	7.3	7.4	7.7	7.3	7.3	7.3	7.2	7.6	7.4	7.4	7.6	7.2	7.2	7.1	7.3	7.4	7.3	7.3	7.2	7.3	7.4	7.1
Half-hourly	Monthly mean	6.9	Mean Half-hourly average	7.0	7.0	7.0	7.0	6.8	6.8	6.9	6.8	6.9	6.8	6.9	6.8	6.9	6.8	6.8	6.8	6.9	6.8	6.8	6.8	6.8	6.8	6.8	6.8	6.8	6.8	6.8	6.8	6.8	6.8	6.8
average	Monthly minimum	5.2	Minimum Half-hourly average	6.3	6.6	6.8	5.2	6.2	6.2	6.5	6.3	6.4	6.3	6.5	6.1	6.4	6.3	6.1	6.4	6.2	6.3	6.3	6.4	6.4	6.4	6.4	6.2	6.4	6.5	6.2	6.3	6.2	6.3	6.4
	Total Invalid results	0	No of Invalid results	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
	Sum of exceedances	0	No of exceedances of ELV	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
			Daily average ELV	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Daily	Monthly maximum	7.0	Daily average	7.0	7.0	7.0	7.0	6.8	6.8	6.9	6.8	6.9	6.8	6.9	6.8	6.9	6.8	6.8	6.8	6.9	6.8	6.8	6.8	6.8	6.8	6.8	6.8	6.8	6.8	6.8	6.8	6.8	6.8	6.8
average	No of invalid days	0	Value Valid?	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y
	Sum of exceedances	0	Value Exceeds ELV?	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N


Signed..... Date.....

(Authorised to sign as a representative of the Operator)

Permit Reference Number : PPC/A/1157446 Operator : Kanadevia Inova UK Operations Ltd

Installation: Earlsgate Energy Center Form Number: Air C (A1)

Reporting of Continuously Monitored Emissions to Air for Moisture % at Emission Point A1 For the month of July 2026



	Monthly summary		Date	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24	25	26	27	28	29	30	31
Half-hourly average			Half-hourly average ELV	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	Monthly maximum	22.2	Maximum Half-hourly average	21.1	20.4	19.4	20.7	20.1	20.1	20.7	21.6	19.7	20.5	20.9	22.2	19.6	19.9	19.5	20.5	20.2	20.1	18.7	19.7	19.1	19.4	19.1	20.1	19.1	18.8	18.4	20.7	20.5	20.6	20.4
	Monthly mean	17.6	Mean Half-hourly average	18.4	17.7	17.8	17.3	17.3	17.4	18.0	18.9	17.8	18.0	17.8	18.3	18.1	17.5	17.5	17.5	17.5	17.1	16.1	17.0	17.6	17.5	17.3	17.2	16.9	16.9	16.9	17.8	18.1	17.8	18.1
	Monthly minimum	12.0	Minimum Half-hourly average	16.6	15.1	15.9	12.0	14.6	15.8	16.6	16.9	15.7	15.6	14.9	15.1	15.9	15.8	15.4	15.0	15.0	14.7	12.5	15.4	16.4	15.2	15.4	15.6	15.1	15.5	15.3	16.4	15.7	15.4	16.5
	Total Invalid results	0	No of Invalid results	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
	Sum of exceedances	0	No of exceedances of ELV	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Daily average			Daily average ELV	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	Monthly maximum	18.9	Daily average	18.4	17.7	17.8	17.3	17.3	17.4	18.0	18.9	17.8	18.0	17.8	18.3	18.1	17.5	17.5	17.5	17.5	17.1	16.1	17.0	17.6	17.5	17.3	17.2	16.9	16.9	16.9	17.8	18.1	17.8	18.1
	No of invalid days	0	Value Valid?	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y
	Sum of exceedances	0	Value Exceeds ELV?	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N

Signed..... Date.....

(Authorised to sign as a representative of the Operator)