
Permit Reference Number : PPC/A/1157446 Operator : Kanadevia Inova UK Operations Ltd

Installation: Earlsgate Energy Center Form Number: Air 3 (A1)

Reporting of Continuously Monitored Emissions to Air for HCl mg/Nm3 at Emission Point A1 For the month of August 2026



	Monthly summary		Date	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24	25	26	27	28	29	30	31
			Half-hourly average ELV	60.0	60.0	60.0	60.0	60.0	60.0	60.0	60.0	60.0	60.0	60.0	60.0	60.0	60.0	60.0	60.0	60.0	60.0	60.0	60.0	60.0	60.0	60.0	60.0	60.0	60.0	60.0	60.0	60.0	60.0	60.0
	Monthly maximum	7.5	Maximum Half-hourly average	7.1	6.5	7.4	7.3	7.5	6.8	5.6	6.4	6.0	6.5	6.8	6.5	6.9	6.9	7.2	7.2	7.5	7.4	7.3	7.3	7.4	7.2	7.4	7.3	7.2	7.3	7.2	7.2	7.2	7.0	7.3
Half-hourly	Monthly mean	5.7	Mean Half-hourly average	6.5	5.2	6.5	6.3	6.3	3.7	3.5	3.9	4.0	4.2	4.4	4.5	4.8	4.8	5.5	6.2	6.7	6.6	6.8	6.5	6.4	6.2	6.6	6.5	6.7	6.3	6.1	6.3	5.8	5.4	6.3
average	Monthly minimum	2.6	Minimum Half-hourly average	5.4	4.0	5.0	5.2	5.1	2.7	2.6	2.9	3.1	3.0	3.0	2.9	2.9	3.2	4.2	4.8	5.4	5.2	5.5	5.1	5.1	5.4	5.3	5.3	5.7	5.3	4.9	5.0	4.2	4.3	4.6
	Total Invalid results	0	No of Invalid results	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
	Sum of exceedances	0	No of exceedances of ELV	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
			Daily average ELV	8.0	8.0	8.0	8.0	8.0	8.0	8.0	8.0	8.0	8.0	8.0	8.0	8.0	8.0	8.0	8.0	8.0	8.0	8.0	8.0	8.0	8.0	8.0	8.0	8.0	8.0	8.0	8.0	8.0	8.0	8.0
Daily	Monthly maximum	6.8	Daily average	6.5	5.2	6.5	6.3	6.3	3.7	3.5	3.9	4.0	4.2	4.4	4.5	4.8	4.8	5.5	6.2	6.7	6.6	6.8	6.5	6.4	6.2	6.6	6.5	6.7	6.3	6.1	6.3	5.8	5.4	6.3
average	No of invalid days	0	Value Valid?	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y
	Sum of exceedances	0	Value Exceeds ELV?	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N


Signed..... Date.....

(Authorised to sign as a representative of the Operator)

Permit Reference Number : PPC/A/1157446 Operator : Kanadevia Inova UK Operations Ltd

Installation: Earlsgate Energy Center Form Number: Air 5 (A1)

Reporting of Continuously Monitored Emissions to Air for SO2 mg/Nm3 at Emission Point A1 For the month of August 2026



	Monthly summary		Date	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24	25	26	27	28	29	30	31
			Half-hourly average ELV	200	200	200	200	200	200	200	200	200	200	200	200	200	200	200	200	200	200	200	200	200	200	200	200	200	200	200	200	200	200	200
Half-hourly average	Monthly maximum	28	Maximum Half-hourly average	8	12	8	9	9	17	14	15	18	15	24	28	17	13	12	13	8	8	8	9	8	11	9	8	8	11	8	11	18	15	8
	Monthly mean	8	Mean Half-hourly average	7	7	7	7	7	8	8	8	8	8	9	9	10	8	7	7	7	7	7	7	7	7	7	6	7	7	7	8	9	9	7
	Monthly minimum	4	Minimum Half-hourly average	6	6	5	5	7	6	5	5	6	6	5	4	5	5	5	5	5	5	5	6	5	5	5	5	5	6	6	7	6	5	6
	Total Invalid results	0	No of Invalid results	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
	Sum of exceedances	0	No of exceedances of ELV	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
			Daily average ELV	40	40	40	40	40	40	40	40	40	40	40	40	40	40	40	40	40	40	40	40	40	40	40	40	40	40	40	40	40	40	40
Daily average	Monthly maximum	10	Daily average	7	7	7	7	7	8	8	8	8	8	9	9	10	8	7	7	7	7	7	7	7	7	7	6	7	7	7	8	9	9	7
	No of invalid days	0	Value Valid?	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y
	Sum of exceedances	0	Value Exceeds ELV?	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N


Signed..... Date.....

(Authorised to sign as a representative of the Operator)

Permit Reference Number : PPC/A/1157446 Operator : Kanadevia Inova UK Operations Ltd

Installation: Earlsgate Energy Center Form Number: Air 6 (A1)

Reporting of Continuously Monitored Emissions to Air for NOx mg/Nm3 at Emission Point A1 For the month of August 2026



	Monthly summary		Date	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24	25	26	27	28	29	30	31
			Half-hourly average ELV	400	400	400	400	400	400	400	400	400	400	400	400	400	400	400	400	400	400	400	400	400	400	400	400	400	400	400	400	400	400	400
	Monthly maximum	195	Maximum Half-hourly average	170	165	195	181	174	182	177	181	179	175	188	170	178	172	169	168	181	168	188	175	172	170	174	174	174	169	180	172	178	178	175
Half-hourly	Monthly mean	153	Mean Half-hourly average	151	152	156	156	150	154	153	151	155	152	153	153	155	156	157	153	150	150	152	151	153	152	152	153	152	154	155	153	152	154	154
average	Monthly minimum	101	Minimum Half-hourly average	126	137	138	122	101	124	122	125	113	134	129	128	136	134	124	117	125	128	118	124	132	125	127	127	122	134	117	113	130	122	124
	Total Invalid results	0	No of Invalid results	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
	Sum of exceedances	0	No of exceedances of ELV	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
			Daily average ELV	180	180	180	180	180	180	180	180	180	180	180	180	180	180	180	180	180	180	180	180	180	180	180	180	180	180	180	180	180	180	180
Daily	Monthly maximum	157	Daily average	151	152	156	156	150	154	153	151	155	152	153	153	155	156	157	153	150	150	152	151	153	152	152	153	152	154	155	153	152	154	154
average	No of invalid days	0	Value Valid?	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y
	Sum of exceedances	0	Value Exceeds ELV?	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N


Signed..... Date.....

(Authorised to sign as a representative of the Operator)

Permit Reference Number : PPC/A/1157446 Operator : Kanadevia Inova UK Operations Ltd

Installation: Earlsgate Energy Center Form Number: Air 2 (A1)

Reporting of Continuously Monitored Emissions to Air for TOC mg/Nm3 at Emission Point A1 For the month of August 2026



	Monthly summary		Date	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24	25	26	27	28	29	30	31
			Half-hourly average ELV	20.0	20.0	20.0	20.0	20.0	20.0	20.0	20.0	20.0	20.0	20.0	20.0	20.0	20.0	20.0	20.0	20.0	20.0	20.0	20.0	20.0	20.0	20.0	20.0	20.0	20.0	20.0	20.0	20.0	20.0	20.0
	Monthly maximum	7.9	Maximum Half-hourly average	4.8	3.8	4.0	3.6	3.7	4.0	3.0	2.8	2.9	2.5	3.6	3.5	2.8	2.3	2.7	7.4	3.0	2.4	2.5	3.4	2.6	4.9	2.8	2.7	5.0	7.9	3.5	2.8	4.3	3.7	3.2
Half-hourly	Monthly mean	2.3	Mean Half-hourly average	3.0	2.1	2.8	2.9	2.9	2.8	2.1	2.3	2.3	1.9	2.4	2.3	2.1	1.8	1.9	2.2	2.0	1.8	1.9	2.4	2.0	2.2	2.0	2.1	1.9	2.0	2.3	2.3	2.7	2.1	2.2
average	Monthly minimum	0.6	Minimum Half-hourly average	0.7	0.6	0.9	1.8	1.1	1.7	1.6	1.6	1.7	1.4	1.6	0.9	1.7	1.4	1.4	0.9	1.5	1.4	1.4	1.9	1.6	1.7	1.3	1.5	1.4	1.4	1.8	1.7	1.8	0.9	1.5
	Total Invalid results	0	No of Invalid results	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
	Sum of exceedances	0	No of exceedances of ELV	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
			Daily average ELV	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0
Daily	Monthly maximum	3.0	Daily average	3.0	2.1	2.8	2.9	2.9	2.8	2.1	2.3	2.3	1.9	2.4	2.3	2.1	1.8	1.9	2.2	2.0	1.8	1.9	2.4	2.0	2.2	2.0	2.1	1.9	2.0	2.3	2.3	2.7	2.1	2.2
average	No of invalid days	0	Value Valid?	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y
	Sum of exceedances	0	Value Exceeds ELV?	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N


Signed..... Date.....

(Authorised to sign as a representative of the Operator)

Permit Reference Number : PPC/A/1157446 Operator : Kanadevia Inova UK Operations Ltd

Installation: Earlsgate Energy Center Form Number: Air 7 (A1)

Reporting of Continuously Monitored Emissions to Air for NH3 mg/Nm3 at Emission Point A1 For the month of August 2026



	Monthly summary		Date	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24	25	26	27	28	29	30	31
Half-hourly average			Half-hourly average ELV	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	Monthly maximum	1.3	Maximum Half-hourly average	0.6	0.5	0.3	0.7	0.5	1.0	0.4	0.4	0.4	0.5	0.5	0.5	0.8	0.5	0.4	0.6	0.6	0.9	0.6	0.6	0.7	0.6	0.5	0.6	0.5	0.8	1.3	0.9	0.7	0.8	1.1
	Monthly mean	0.4	Mean Half-hourly average	0.3	0.3	0.3	0.3	0.3	0.4	0.3	0.3	0.3	0.4	0.4	0.3	0.4	0.4	0.3	0.4	0.3	0.4	0.4	0.4	0.4	0.3	0.3	0.4	0.4	0.4	0.5	0.6	0.5	0.5	0.5
	Monthly minimum	0.2	Minimum Half-hourly average	0.2	0.2	0.2	0.2	0.3	0.2	0.2	0.2	0.2	0.3	0.3	0.2	0.2	0.3	0.2	0.2	0.2	0.2	0.3	0.3	0.3	0.2	0.3	0.3	0.3	0.3	0.2	0.4	0.3	0.4	0.3
	Total Invalid results	0	No of Invalid results	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
	Sum of exceedances	0	No of exceedances of ELV	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Daily average			Daily average ELV	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0
	Monthly maximum	0.6	Daily average	0.3	0.3	0.3	0.3	0.3	0.4	0.3	0.3	0.3	0.4	0.4	0.3	0.4	0.4	0.3	0.4	0.3	0.4	0.4	0.4	0.4	0.3	0.3	0.4	0.4	0.4	0.5	0.6	0.5	0.5	0.5
	No of invalid days	0	Value Valid?	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y
	Sum of exceedances	0	Value Exceeds ELV?	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N


Signed..... Date.....

(Authorised to sign as a representative of the Operator)

Permit Reference Number : PPC/A/1157446 Operator : Kanadevia Inova UK Operations Ltd

Installation: Earlsgate Energy Center Form Number: Air 1 (A1)

Reporting of Continuously Monitored Emissions to Air for Particulates mg/Nm3 at Emission Point A1 For the month of August 2026



	Monthly summary		Date	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24	25	26	27	28	29	30	31
			Half-hourly average ELV	30.0	30.0	30.0	30.0	30.0	30.0	30.0	30.0	30.0	30.0	30.0	30.0	30.0	30.0	30.0	30.0	30.0	30.0	30.0	30.0	30.0	30.0	30.0	30.0	30.0	30.0	30.0	30.0	30.0	30.0	30.0
	Monthly maximum	0.1	Maximum Half-hourly average	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1
Half-hourly	Monthly mean	0.1	Mean Half-hourly average	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1
average	Monthly minimum	0.1	Minimum Half-hourly average	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1
	Total Invalid results	0	No of Invalid results	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
	Sum of exceedances	0	No of exceedances of ELV	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
			Daily average ELV	5.0	5.0	5.0	5.0	5.0	5.0	5.0	5.0	5.0	5.0	5.0	5.0	5.0	5.0	5.0	5.0	5.0	5.0	5.0	5.0	5.0	5.0	5.0	5.0	5.0	5.0	5.0	5.0	5.0	5.0	5.0
Daily	Monthly maximum	0.1	Daily average	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1
average	No of invalid days	0	Value Valid?	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y
	Sum of exceedances	0	Value Exceeds ELV?	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N


Signed..... Date.....

(Authorised to sign as a representative of the Operator)

Permit Reference Number : PPC/A/1157446 Operator : Kanadevia Inova UK Operations Ltd

Installation: Earlsgate Energy Center Form Number: Air 8 (A1)

Reporting of Continuously Monitored Emissions to Air for N2O mg/Nm3 at Emission Point A1 For the month of August 2026



	Monthly summary		Date	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24	25	26	27	28	29	30	31
			Half-hourly average ELV	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	Monthly maximum	11.3	Maximum Half-hourly average	5.3	5.1	4.6	5.7	11.3	3.6	4.2	4.4	4.4	5.7	4.5	4.8	5.6	6.2	6.2	5.1	4.2	6.0	5.9	8.8	4.7	4.3	6.8	4.9	6.6	4.8	5.0	7.0	8.3	9.7	5.1
Half-hourly	Monthly mean	2.9	Mean Half-hourly average	2.8	2.9	2.7	2.8	2.9	2.1	2.7	2.7	2.3	3.4	3.2	3.3	3.4	3.1	3.0	2.7	2.7	3.6	3.1	3.3	3.3	2.7	2.7	2.9	2.8	2.8	3.1	3.0	3.2	3.4	3.0
average	Monthly minimum	0.6	Minimum Half-hourly average	1.0	1.5	1.0	0.8	1.1	0.6	0.9	0.7	0.6	2.1	1.2	1.3	2.0	1.9	1.8	1.4	1.5	1.4	1.1	1.8	2.4	1.2	1.5	1.8	1.8	1.4	1.5	1.9	1.1	1.8	2.0
	Total Invalid results	0	No of Invalid results	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
	Sum of exceedances	0	No of exceedances of ELV	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
			Daily average ELV	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Daily	Monthly maximum	3.6	Daily average	2.8	2.9	2.7	2.8	2.9	2.1	2.7	2.7	2.3	3.4	3.2	3.3	3.4	3.1	3.0	2.7	2.7	3.6	3.1	3.3	3.3	2.7	2.7	2.9	2.8	2.8	3.1	3.0	3.2	3.4	3.0
average	No of invalid days	0	Value Valid?	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y
	Sum of exceedances	0	Value Exceeds ELV?	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N


Signed..... Date.....

(Authorised to sign as a representative of the Operator)

Permit Reference Number : PPC/A/1157446 Operator : Kanadevia Inova UK Operations Ltd

Installation: Earlsgate Energy Center Form Number: Air 4 (A1)

Reporting of Continuously Monitored Emissions to Air for CO mg/Nm3 at Emission Point A1 For the month of August 2026



	Monthly summary		Date	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24	25	26	27	28	29	30	31
10 Minute average			10 Minute average ELV (95th Percentile)	150	150	150	150	150	150	150	150	150	150	150	150	150	150	150	150	150	150	150	150	150	150	150	150	150	150	150	150	150	150	150
	Monthly Maximum 10-min	679	Maximum 10 Minute average	58	174	9	40	66	172	89	6	4	127	36	83	136	43	81	225	111	41	11	163	20	324	154	29	246	204	100	29	171	679	62
	Monthly mean 10-min avgs	3	95th Percentile	6	15	5	5	5	5	3	3	3	2	4	4	6	3	4	4	3	2	2	4	3	3	2	3	3	4	3	4	6	11	3
	Monthly Minimum 10-min	0	Minimum 10 Minute average	0	0	0	2	0	1	0	1	0	0	0	0	0	0	0	0	0	0	0	1	0	0	0	0	0	0	0	0	1	0	0
	Total Invalid results	0	No of Invalid results	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
			Number of results above 150mg/m³	0	1	0	0	0	1	0	0	0	0	0	0	0	0	0	1	0	0	0	1	0	1	1	0	1	1	0	0	2	3	0
	Sum of Exceedances of 95th percentile ELV	0	95th Percentile ELV Exceeded (Y/N)	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N
Daily average			Daily average ELV	50	50	50	50	50	50	50	50	50	50	50	50	50	50	50	50	50	50	50	50	50	50	50	50	50	50	50	50	50	50	50
	Monthly maximum	11	Daily average	4	7	3	4	4	5	3	2	2	3	2	3	4	1	2	4	3	2	1	3	2	5	3	2	4	3	3	2	6	11	2
	No of invalid days	0	Value Valid?	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y
	Sum of exceedances	0	Value Exceeds ELV? (Y/N)	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N

Signed..... Date.....


(Authorised to sign as a representative of the Operator)

Environment Agency explanatory note: The 10-minute average ELV is based on the "95th percentile" In this case this means that 95% of the 10 minute averages in the calendar day (= 137) must be below 150 mg/m3, and 5% (= 7) are allowed to be any value above 150 mg/m3. Whilst we expect operators to minimise CO emissions at all times, it is perfectly acceptable for the value of the maximum 10-minute average to be above 150 mg/m3, provided the 95th percentile ELV has been met for that period

Permit Reference Number : PPC/A/1157446 Operator : Kanadevia Inova UK Operations Ltd

Installation: Earlsgate Energy Center Form Number: Air A (A1)

Reporting of Continuously Monitored Emissions to Air for CO2 % at Emission Point A1 For the month of August 2026



	Monthly summary		Date	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24	25	26	27	28	29	30	31
			Half-hourly average ELV	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	Monthly maximum	8.4	Maximum Half-hourly average	8.2	8.3	8.2	8.4	8.1	8.3	8.3	8.2	8.2	8.2	8.3	8.3	8.2	8.2	8.3	8.3	8.2	8.2	8.2	8.2	8.2	8.3	8.3	8.3	8.3	8.3	8.3	8.2	8.1	8.2	8.3
Half-hourly	Monthly mean	8.1	Mean Half-hourly average	8.1	8.1	8.1	8.1	8.0	8.1	8.1	8.1	8.1	8.1	8.1	8.2	8.1	8.1	8.1	8.1	8.1	8.1	8.0	8.1	8.1	8.2	8.2	8.1	8.2	8.2	8.1	8.1	8.0	8.0	8.1
average	Monthly minimum	7.3	Minimum Half-hourly average	8.0	8.0	8.0	8.0	7.3	8.1	8.0	8.0	8.0	8.0	8.1	8.1	8.0	8.0	8.1	8.0	8.0	8.0	7.9	7.9	7.5	8.1	8.1	8.1	8.1	8.1	8.0	8.0	7.9	7.9	8.0
	Total Invalid results	0	No of Invalid results	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
	Sum of exceedances	0	No of exceedances of ELV	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
			Daily average ELV	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Daily	Monthly maximum	8.2	Daily average	8.1	8.1	8.1	8.1	8.0	8.1	8.1	8.1	8.1	8.1	8.1	8.2	8.1	8.1	8.1	8.1	8.1	8.1	8.0	8.1	8.1	8.2	8.2	8.1	8.2	8.2	8.1	8.1	8.0	8.0	8.1
average	No of invalid days	0	Value Valid?	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y
	Sum of exceedances	0	Value Exceeds ELV?	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N


Signed..... Date.....

(Authorised to sign as a representative of the Operator)

Permit Reference Number : PPC/A/1157446 Operator : Kanadevia Inova UK Operations Ltd

Installation: Earlsgate Energy Center Form Number: Air B (A1)

Reporting of Continuously Monitored Emissions to Air for Dry Oxygen % at Emission Point A1 For the month of August 2026



	Monthly summary		Date	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24	25	26	27	28	29	30	31
			Half-hourly average ELV	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	Monthly maximum	10.3	Maximum Half-hourly average	7.3	7.4	7.2	7.1	10.3	7.3	7.1	7.3	7.2	7.4	7.1	7.1	7.2	7.4	7.5	7.1	7.1	7.2	7.3	7.3	7.1	7.4	7.5	7.2	7.5	7.3	7.2	7.2	7.9	7.5	7.3
Half-hourly	Monthly mean	6.8	Mean Half-hourly average	6.8	6.8	6.9	6.8	7.1	6.7	6.8	6.8	6.8	6.8	6.8	6.8	6.8	6.8	6.8	6.8	6.8	6.8	6.9	6.8	6.8	6.8	6.8	6.8	6.8	6.8	6.8	6.8	6.9	6.8	6.8
average	Monthly minimum	6.1	Minimum Half-hourly average	6.4	6.2	6.5	6.5	6.6	6.2	6.1	6.5	6.4	6.4	6.2	6.5	6.5	6.4	6.3	6.3	6.3	6.1	6.6	6.2	6.4	6.5	6.1	6.5	6.4	6.3	6.5	6.4	6.3	6.1	6.1
	Total Invalid results	0	No of Invalid results	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
	Sum of exceedances	0	No of exceedances of ELV	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
			Daily average ELV	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Daily	Monthly maximum	7.1	Daily average	6.8	6.8	6.9	6.8	7.1	6.7	6.8	6.8	6.8	6.8	6.8	6.8	6.8	6.8	6.8	6.8	6.8	6.8	6.9	6.8	6.8	6.8	6.8	6.8	6.8	6.8	6.8	6.8	6.9	6.8	6.8
average	No of invalid days	0	Value Valid?	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y
	Sum of exceedances	0	Value Exceeds ELV?	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N


Signed..... Date.....

(Authorised to sign as a representative of the Operator)

Permit Reference Number : PPC/A/1157446 Operator : Kanadevia Inova UK Operations Ltd

Installation: Earlsgate Energy Center Form Number: Air C (A1)

Reporting of Continuously Monitored Emissions to Air for Moisture % at Emission Point A1 For the month of August 2026



	Monthly summary		Date	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24	25	26	27	28	29	30	31
			Half-hourly average ELV	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	Monthly maximum	21.0	Maximum Half-hourly average	19.3	19.1	19.4	20.1	19.8	19.9	20.8	19.5	21.0	19.5	20.0	19.6	19.9	20.1	19.5	19.1	20.3	21.0	19.8	20.8	20.2	20.7	18.6	19.0	19.7	19.7	20.1	20.6	18.8	20.3	20.4
Half-hourly	Monthly mean	17.5	Mean Half-hourly average	17.4	17.0	17.4	18.1	17.7	18.3	17.9	17.3	17.5	17.4	17.3	17.7	17.8	18.0	17.0	17.0	17.3	17.4	17.8	18.0	18.1	17.0	16.7	17.3	17.7	18.0	18.0	17.8	16.8	16.2	17.2
average	Monthly minimum	10.9	Minimum Half-hourly average	16.0	14.7	16.2	16.2	10.9	17.0	15.9	14.7	14.9	15.0	14.1	15.6	16.1	15.7	14.1	14.3	15.6	16.0	16.1	14.2	16.4	13.7	14.0	14.9	15.4	14.5	16.1	14.0	13.5	13.3	15.6
	Total Invalid results	0	No of Invalid results	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
	Sum of exceedances	0	No of exceedances of ELV	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
			Daily average ELV	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Daily	Monthly maximum	18.3	Daily average	17.4	17.0	17.4	18.1	17.7	18.3	17.9	17.3	17.5	17.4	17.3	17.7	17.8	18.0	17.0	17.0	17.3	17.4	17.8	18.0	18.1	17.0	16.7	17.3	17.7	18.0	18.0	17.8	16.8	16.2	17.2
average	No of invalid days	0	Value Valid?	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y
	Sum of exceedances	0	Value Exceeds ELV?	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N

Signed..... Date.....

(Authorised to sign as a representative of the Operator)