

Permit Reference Number : PPC/A/1157446


Operator : Kanadevia Inova UK Operations Ltd

Installation: Earlsgate Energy Center

Form Number: Air 3 (A1)

Reporting of Continuously Monitored Emissions to Air for HCl mg/Nm3 at Emission Point A1 For the month of July 2025

Daily and Half-hourly Average Monitoring Data



| Monthly summary | | Date | 1 | 2 | 3 | 4 | 5 | 6 | 7 | 8 | 9 | 10 | 11 | 12 | 13 | 14 | 15 | 16 | 17 | 18 | 19 | 20 | 21 | 22 | 23 | 24 | 25 | 26 | 27 | 28 | 29 | 30 | 31 | | |
|---------------------|-----------------------|-------------------------|-----------------------------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|-----|---|
| Half-hourly average | | Half-hourly average ELV | 60.0 | 60.0 | 60.0 | 60.0 | 60.0 | 60.0 | 60.0 | 60.0 | 60.0 | 60.0 | 60.0 | 60.0 | 60.0 | 60.0 | 60.0 | 60.0 | 60.0 | 60.0 | 60.0 | 60.0 | 60.0 | 60.0 | 60.0 | 60.0 | 60.0 | 60.0 | 60.0 | 60.0 | 60.0 | 60.0 | 60.0 | | |
| | Monthly maximum | 7.9 | Maximum Half-hourly average | 6.8 | 7.5 | 7.8 | 7.5 | 6.8 | 7.2 | 7.6 | 7.4 | 7.9 | 7.4 | 7.3 | 7.2 | 7.2 | 7.0 | 7.2 | 7.3 | 7.0 | 6.4 | 5.2 | 6.4 | 7.1 | 6.7 | 5.2 | 7.9 | 5.2 | 6.8 | 4.3 | 6.4 | 7.0 | 7.0 | 7.5 | |
| | Monthly mean | 5.2 | Mean Half-hourly average | 4.1 | 5.5 | 5.4 | 6.0 | 5.2 | 5.6 | 6.3 | 6.4 | 6.2 | 5.8 | 6.0 | 5.7 | 6.6 | 6.4 | 6.6 | 5.9 | 5.2 | 3.5 | 3.8 | 5.1 | 4.4 | 4.3 | 4.4 | 5.3 | 3.5 | 4.3 | 3.1 | 4.3 | 4.6 | 5.0 | 5.9 | |
| | Monthly minimum | 2.3 | Minimum Half-hourly average | 3.3 | 3.8 | 4.6 | 4.9 | 4.3 | 4.3 | 5.1 | 5.3 | 5.2 | 4.8 | 5.0 | 3.9 | 5.4 | 5.3 | 5.3 | 4.6 | 3.3 | 2.5 | 2.8 | 3.9 | 3.3 | 3.3 | 3.5 | 3.4 | 2.8 | 2.9 | 2.3 | 3.5 | 3.2 | 3.4 | 3.9 | |
| | Total Invalid results | 0 | No of Invalid results | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| | Sum of exceedances | 0 | No of exceedances of ELV | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| Daily average | | Daily average ELV | 8.0 | 8.0 | 8.0 | 8.0 | 8.0 | 8.0 | 8.0 | 8.0 | 8.0 | 8.0 | 8.0 | 8.0 | 8.0 | 8.0 | 8.0 | 8.0 | 8.0 | 8.0 | 8.0 | 8.0 | 8.0 | 8.0 | 8.0 | 8.0 | 8.0 | 8.0 | 8.0 | 8.0 | 8.0 | 8.0 | 8.0 | | |
| | Monthly maximum | 6.6 | Daily average | 4.1 | 5.5 | 5.4 | 6.0 | 5.2 | 5.6 | 6.3 | 6.4 | 6.2 | 5.8 | 6.0 | 5.7 | 6.6 | 6.4 | 6.6 | 5.9 | 5.2 | 3.5 | 3.8 | 5.1 | 4.4 | 4.3 | 4.4 | 5.3 | 3.5 | 4.3 | 3.1 | 4.3 | 4.6 | 5.0 | 5.9 | |
| | No of invalid days | 0 | Value Valid? | Y | Y | Y | Y | Y | Y | Y | Y | Y | Y | Y | Y | Y | Y | Y | Y | Y | Y | Y | Y | Y | Y | Y | Y | Y | Y | Y | Y | Y | Y | Y | |
| | Sum of exceedances | 0 | Value Exceeds ELV? | N | N | N | N | N | N | N | N | N | N | N | N | N | N | N | N | N | N | N | N | N | N | N | N | N | N | N | N | N | N | N | N |

Signed.....REDACTED.....

Date.....06.10.25.....

(Authorised to sign as a representative of the Operator)

Permit Reference Number : PPC/A/1157446


Operator : Kanadevia Inova UK Operations Ltd

Installation: Earlsgate Energy Center

Form Number: Air 5 (A1)

Reporting of Continuously Monitored Emissions to Air for SO2 mg/Nm3 at Emission Point A1 For the month of July 2025

Daily and Half-hourly Average Monitoring Data



| Monthly summary | | Date | 1 | 2 | 3 | 4 | 5 | 6 | 7 | 8 | 9 | 10 | 11 | 12 | 13 | 14 | 15 | 16 | 17 | 18 | 19 | 20 | 21 | 22 | 23 | 24 | 25 | 26 | 27 | 28 | 29 | 30 | 31 | |
|---------------------|-----------------------|-------------------------|-----------------------------|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|----|
| Half-hourly average | | Half-hourly average ELV | 200 | 200 | 200 | 200 | 200 | 200 | 200 | 200 | 200 | 200 | 200 | 200 | 200 | 200 | 200 | 200 | 200 | 200 | 200 | 200 | 200 | 200 | 200 | 200 | 200 | 200 | 200 | 200 | 200 | 200 | 200 | |
| | Monthly maximum | 24 | Maximum Half-hourly average | 14 | 8 | 8 | 10 | 11 | 9 | 9 | 5 | 6 | 7 | 9 | 8 | 7 | 9 | 7 | 10 | 14 | 21 | 7 | 9 | 20 | 19 | 6 | 24 | 18 | 23 | 9 | 19 | 21 | 15 | 10 |
| | Monthly mean | 6 | Mean Half-hourly average | 5 | 5 | 5 | 5 | 6 | 6 | 5 | 4 | 4 | 5 | 5 | 6 | 6 | 6 | 6 | 6 | 7 | 6 | 5 | 6 | 6 | 6 | 5 | 5 | 5 | 6 | 5 | 6 | 7 | 7 | 5 |
| | Monthly minimum | 0 | Minimum Half-hourly average | 3 | 3 | 3 | 3 | 3 | 4 | 4 | 3 | 0 | 3 | 4 | 4 | 3 | 4 | 3 | 0 | 5 | 4 | 4 | 4 | 4 | 4 | 4 | 3 | 3 | 3 | 4 | 4 | 4 | 1 | 4 |
| | Total Invalid results | 0 | No of Invalid results | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| | Sum of exceedances | 0 | No of exceedances of ELV | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| Daily average | | Daily average ELV | 40 | 40 | 40 | 40 | 40 | 40 | 40 | 40 | 40 | 40 | 40 | 40 | 40 | 40 | 40 | 40 | 40 | 40 | 40 | 40 | 40 | 40 | 40 | 40 | 40 | 40 | 40 | 40 | 40 | 40 | 40 | |
| | Monthly maximum | 7 | Daily average | 5 | 5 | 5 | 5 | 6 | 6 | 5 | 4 | 4 | 5 | 5 | 6 | 6 | 6 | 6 | 6 | 7 | 6 | 5 | 6 | 6 | 6 | 5 | 5 | 5 | 6 | 5 | 6 | 7 | 7 | 5 |
| | No of invalid days | 0 | Value Valid? | Y | Y | Y | Y | Y | Y | Y | Y | Y | Y | Y | Y | Y | Y | Y | Y | Y | Y | Y | Y | Y | Y | Y | Y | Y | Y | Y | Y | Y | Y | |
| | Sum of exceedances | 0 | Value Exceeds ELV? | N | N | N | N | N | N | N | N | N | N | N | N | N | N | N | N | N | N | N | N | N | N | N | N | N | N | N | N | N | N | N |

Signed.....REDACTED.....

Date.....06.10.25.....

(Authorised to sign as a representative of the Operator)

Permit Reference Number : PPC/A/1157446


Operator : Kanadevia Inova UK Operations Ltd

Installation: Earlsgate Energy Center

Form Number: Air 6 (A1)

Reporting of Continuously Monitored Emissions to Air for NOx mg/Nm3 at Emission Point A1 For the month of July 2025

Daily and Half-hourly Average Monitoring Data



| Monthly summary | | Date | 1 | 2 | 3 | 4 | 5 | 6 | 7 | 8 | 9 | 10 | 11 | 12 | 13 | 14 | 15 | 16 | 17 | 18 | 19 | 20 | 21 | 22 | 23 | 24 | 25 | 26 | 27 | 28 | 29 | 30 | 31 | | |
|---------------------|-----------------------|-------------------------|-----------------------------|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|
| Half-hourly average | | Half-hourly average ELV | 400 | 400 | 400 | 400 | 400 | 400 | 400 | 400 | 400 | 400 | 400 | 400 | 400 | 400 | 400 | 400 | 400 | 400 | 400 | 400 | 400 | 400 | 400 | 400 | 400 | 400 | 400 | 400 | 400 | 400 | 400 | | |
| | Monthly maximum | 209 | Maximum Half-hourly average | 165 | 205 | 165 | 209 | 163 | 171 | 176 | 167 | 166 | 168 | 175 | 163 | 163 | 163 | 162 | 164 | 166 | 158 | 163 | 173 | 172 | 172 | 167 | 166 | 168 | 189 | 168 | 160 | 167 | 167 | 175 | |
| | Monthly mean | 152 | Mean Half-hourly average | 152 | 154 | 151 | 152 | 152 | 152 | 153 | 151 | 152 | 151 | 151 | 152 | 152 | 153 | 151 | 152 | 152 | 152 | 152 | 153 | 154 | 151 | 152 | 151 | 152 | 153 | 153 | 153 | 152 | 152 | 152 | 152 |
| | Monthly minimum | 103 | Minimum Half-hourly average | 136 | 122 | 137 | 131 | 128 | 125 | 124 | 120 | 141 | 123 | 119 | 123 | 140 | 144 | 113 | 142 | 144 | 144 | 146 | 127 | 107 | 103 | 136 | 128 | 130 | 129 | 127 | 143 | 139 | 141 | 132 | |
| | Total Invalid results | 0 | No of Invalid results | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| | Sum of exceedances | 0 | No of exceedances of ELV | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| Daily average | | Daily average ELV | 180 | 180 | 180 | 180 | 180 | 180 | 180 | 180 | 180 | 180 | 180 | 180 | 180 | 180 | 180 | 180 | 180 | 180 | 180 | 180 | 180 | 180 | 180 | 180 | 180 | 180 | 180 | 180 | 180 | 180 | 180 | | |
| | Monthly maximum | 154 | Daily average | 152 | 154 | 151 | 152 | 152 | 152 | 153 | 151 | 152 | 151 | 151 | 152 | 152 | 153 | 151 | 152 | 152 | 152 | 152 | 153 | 154 | 151 | 152 | 151 | 152 | 153 | 153 | 152 | 152 | 152 | 152 | |
| | No of invalid days | 0 | Value Valid? | Y | Y | Y | Y | Y | Y | Y | Y | Y | Y | Y | Y | Y | Y | Y | Y | Y | Y | Y | Y | Y | Y | Y | Y | Y | Y | Y | Y | Y | Y | Y | |
| | Sum of exceedances | 0 | Value Exceeds ELV? | N | N | N | N | N | N | N | N | N | N | N | N | N | N | N | N | N | N | N | N | N | N | N | N | N | N | N | N | N | N | N | |

Signed.....REDACTED.....

Date.....06.10.25.....

(Authorised to sign as a representative of the Operator)

Permit Reference Number : PPC/A/1157446


Operator : Kanadevia Inova UK Operations Ltd

Installation: Earlsgate Energy Center

Form Number: Air 2 (A1)

Reporting of Continuously Monitored Emissions to Air for TOC mg/Nm3 at Emission Point A1 For the month of July 2025

Daily and Half-hourly Average Monitoring Data



| Monthly summary | | Date | 1 | 2 | 3 | 4 | 5 | 6 | 7 | 8 | 9 | 10 | 11 | 12 | 13 | 14 | 15 | 16 | 17 | 18 | 19 | 20 | 21 | 22 | 23 | 24 | 25 | 26 | 27 | 28 | 29 | 30 | 31 | | |
|---------------------|-----------------------|-------------------------|-----------------------------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|---|
| Half-hourly average | | Half-hourly average ELV | 20.0 | 20.0 | 20.0 | 20.0 | 20.0 | 20.0 | 20.0 | 20.0 | 20.0 | 20.0 | 20.0 | 20.0 | 20.0 | 20.0 | 20.0 | 20.0 | 20.0 | 20.0 | 20.0 | 20.0 | 20.0 | 20.0 | 20.0 | 20.0 | 20.0 | 20.0 | 20.0 | 20.0 | 20.0 | 20.0 | 20.0 | | |
| | Monthly maximum | 6.7 | Maximum Half-hourly average | 5.9 | 3.9 | 3.1 | 3.1 | 4.1 | 4.3 | 3.1 | 3.1 | 3.1 | 3.6 | 5.9 | 3.8 | 2.9 | 3.1 | 2.5 | 2.8 | 3.9 | 6.7 | 4.1 | 3.3 | 2.9 | 3.5 | 3.8 | 4.2 | 3.8 | 4.1 | 4.5 | 4.3 | 3.9 | 4.9 | 4.2 | |
| | Monthly mean | 2.5 | Mean Half-hourly average | 1.8 | 2.4 | 2.0 | 2.0 | 2.6 | 2.8 | 2.2 | 2.2 | 2.4 | 2.6 | 2.5 | 2.6 | 2.5 | 2.2 | 2.0 | 2.2 | 2.5 | 3.1 | 2.8 | 2.6 | 2.1 | 2.6 | 2.6 | 2.7 | 2.6 | 2.6 | 2.7 | 2.5 | 2.7 | 3.0 | 3.0 | |
| | Monthly minimum | 0.8 | Minimum Half-hourly average | 0.8 | 1.7 | 0.9 | 0.9 | 1.5 | 1.7 | 1.6 | 0.9 | 1.7 | 1.7 | 2.0 | 1.5 | 2.1 | 1.7 | 1.6 | 1.3 | 0.9 | 2.4 | 2.0 | 2.1 | 0.9 | 2.1 | 1.9 | 1.9 | 1.9 | 1.9 | 2.1 | 1.9 | 2.1 | 2.4 | 1.0 | |
| | Total Invalid results | 0 | No of Invalid results | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| | Sum of exceedances | 0 | No of exceedances of ELV | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| Daily average | | Daily average ELV | 10.0 | 10.0 | 10.0 | 10.0 | 10.0 | 10.0 | 10.0 | 10.0 | 10.0 | 10.0 | 10.0 | 10.0 | 10.0 | 10.0 | 10.0 | 10.0 | 10.0 | 10.0 | 10.0 | 10.0 | 10.0 | 10.0 | 10.0 | 10.0 | 10.0 | 10.0 | 10.0 | 10.0 | 10.0 | 10.0 | 10.0 | 10.0 | |
| | Monthly maximum | 3.1 | Daily average | 1.8 | 2.4 | 2.0 | 2.0 | 2.6 | 2.8 | 2.2 | 2.2 | 2.4 | 2.6 | 2.5 | 2.6 | 2.5 | 2.2 | 2.0 | 2.2 | 2.5 | 3.1 | 2.8 | 2.6 | 2.1 | 2.6 | 2.6 | 2.7 | 2.6 | 2.6 | 2.7 | 2.5 | 2.7 | 3.0 | 3.0 | |
| | No of invalid days | 0 | Value Valid? | Y | Y | Y | Y | Y | Y | Y | Y | Y | Y | Y | Y | Y | Y | Y | Y | Y | Y | Y | Y | Y | Y | Y | Y | Y | Y | Y | Y | Y | Y | Y | |
| | Sum of exceedances | 0 | Value Exceeds ELV? | N | N | N | N | N | N | N | N | N | N | N | N | N | N | N | N | N | N | N | N | N | N | N | N | N | N | N | N | N | N | N | N |

Signed.....REDACTED.....

Date.....06.10.25.....

(Authorised to sign as a representative of the Operator)

Permit Reference Number : PPC/A/1157446


Operator : Kanadevia Inova UK Operations Ltd

Installation: Earlsgate Energy Center

Form Number: Air 7 (A1)

Reporting of Continuously Monitored Emissions to Air for NH3 mg/Nm3 at Emission Point A1 For the month of July 2025

Daily and Half-hourly Average Monitoring Data



| Monthly summary | | Date | 1 | 2 | 3 | 4 | 5 | 6 | 7 | 8 | 9 | 10 | 11 | 12 | 13 | 14 | 15 | 16 | 17 | 18 | 19 | 20 | 21 | 22 | 23 | 24 | 25 | 26 | 27 | 28 | 29 | 30 | 31 | | |
|---------------------|-----------------------|-------------------------|-----------------------------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|-----|-----|
| Half-hourly average | | Half-hourly average ELV | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | |
| | Monthly maximum | 1.0 | Maximum Half-hourly average | 0.5 | 0.3 | 0.1 | 0.1 | 0.2 | 0.6 | 0.2 | 0.1 | 0.2 | 0.3 | 0.4 | 0.3 | 0.5 | 0.3 | 0.3 | 0.3 | 0.4 | 0.6 | 0.2 | 0.2 | 0.5 | 0.2 | 0.1 | 0.3 | 0.2 | 0.1 | 1.0 | 0.3 | 0.2 | 0.3 | 0.2 | |
| | Monthly mean | 0.1 | Mean Half-hourly average | 0.1 | 0.1 | 0.1 | 0.1 | 0.1 | 0.2 | 0.1 | 0.1 | 0.1 | 0.2 | 0.2 | 0.2 | 0.2 | 0.2 | 0.1 | 0.2 | 0.2 | 0.2 | 0.1 | 0.1 | 0.2 | 0.1 | 0.1 | 0.1 | 0.1 | 0.0 | 0.2 | 0.1 | 0.1 | 0.1 | 0.1 | |
| | Monthly minimum | 0.0 | Minimum Half-hourly average | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.1 | 0.1 | 0.1 | 0.2 | 0.1 | 0.0 | 0.1 | 0.1 | 0.1 | 0.1 | 0.1 | 0.1 | 0.1 | 0.0 | 0.0 | 0.0 | 0.0 | 0.1 | 0.0 | 0.0 | 0.0 | 0.0 | |
| | Total Invalid results | 0 | No of Invalid results | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| | Sum of exceedances | 0 | No of exceedances of ELV | N/A | N/A | N/A |
| Daily average | | Daily average ELV | 10.0 | 10.0 | 10.0 | 10.0 | 10.0 | 10.0 | 10.0 | 10.0 | 10.0 | 10.0 | 10.0 | 10.0 | 10.0 | 10.0 | 10.0 | 10.0 | 10.0 | 10.0 | 10.0 | 10.0 | 10.0 | 10.0 | 10.0 | 10.0 | 10.0 | 10.0 | 10.0 | 10.0 | 10.0 | 10.0 | 10.0 | | |
| | Monthly maximum | 0.2 | Daily average | 0.1 | 0.1 | 0.1 | 0.1 | 0.1 | 0.2 | 0.1 | 0.1 | 0.1 | 0.2 | 0.2 | 0.2 | 0.2 | 0.2 | 0.1 | 0.2 | 0.2 | 0.2 | 0.1 | 0.1 | 0.2 | 0.1 | 0.1 | 0.1 | 0.1 | 0.0 | 0.2 | 0.1 | 0.1 | 0.1 | 0.1 | |
| | No of invalid days | 0 | Value Valid? | Y | Y | Y | Y | Y | Y | Y | Y | Y | Y | Y | Y | Y | Y | Y | Y | Y | Y | Y | Y | Y | Y | Y | Y | Y | Y | Y | Y | Y | Y | Y | |
| | Sum of exceedances | 0 | Value Exceeds ELV? | N | N | N | N | N | N | N | N | N | N | N | N | N | N | N | N | N | N | N | N | N | N | N | N | N | N | N | N | N | N | N | N |

Signed.....REDACTED.....

Date.....06.10.25.....

(Authorised to sign as a representative of the Operator)


Permit Reference Number : PPC/A/1157446

Operator : Kanadevia Inova UK Operations Ltd

Installation: Earlsgate Energy Center

Form Number: Air 1 (A1)

Reporting of Continuously Monitored Emissions to Air for Particulates mg/Nm3 at Emission Point A1 For the month of July 2025



| Monthly summary | | Date | 1 | 2 | 3 | 4 | 5 | 6 | 7 | 8 | 9 | 10 | 11 | 12 | 13 | 14 | 15 | 16 | 17 | 18 | 19 | 20 | 21 | 22 | 23 | 24 | 25 | 26 | 27 | 28 | 29 | 30 | 31 | |
|---------------------|-----------------------|-------------------------|-----------------------------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|---|
| Half-hourly average | | Half-hourly average ELV | 30.0 | 30.0 | 30.0 | 30.0 | 30.0 | 30.0 | 30.0 | 30.0 | 30.0 | 30.0 | 30.0 | 30.0 | 30.0 | 30.0 | 30.0 | 30.0 | 30.0 | 30.0 | 30.0 | 30.0 | 30.0 | 30.0 | 30.0 | 30.0 | 30.0 | 30.0 | 30.0 | 30.0 | 30.0 | 30.0 | 30.0 | |
| | Monthly maximum | 0.4 | Maximum Half-hourly average | 0.2 | 0.1 | 0.2 | 0.2 | 0.2 | 0.2 | 0.2 | 0.1 | 0.1 | 0.2 | 0.2 | 0.2 | 0.2 | 0.2 | 0.2 | 0.4 | 0.2 | 0.2 | 0.2 | 0.2 | 0.2 | 0.2 | 0.1 | 0.2 | 0.1 | 0.1 | 0.1 | 0.1 | 0.1 | 0.2 | |
| | Monthly mean | 0.1 | Mean Half-hourly average | 0.1 | 0.1 | 0.1 | 0.2 | 0.1 | 0.1 | 0.1 | 0.1 | 0.1 | 0.1 | 0.2 | 0.1 | 0.1 | 0.2 | 0.2 | 0.2 | 0.2 | 0.2 | 0.1 | 0.2 | 0.2 | 0.2 | 0.1 | 0.1 | 0.1 | 0.1 | 0.1 | 0.1 | 0.1 | 0.1 | |
| | Monthly minimum | 0.1 | Minimum Half-hourly average | 0.1 | 0.1 | 0.1 | 0.1 | 0.1 | 0.1 | 0.1 | 0.1 | 0.1 | 0.1 | 0.1 | 0.1 | 0.1 | 0.1 | 0.1 | 0.1 | 0.2 | 0.1 | 0.1 | 0.1 | 0.1 | 0.1 | 0.1 | 0.1 | 0.1 | 0.1 | 0.1 | 0.1 | 0.1 | 0.1 | |
| | Total Invalid results | 0 | No of Invalid results | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| | Sum of exceedances | 0 | No of exceedances of ELV | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| Daily average | | Daily average ELV | 5.0 | 5.0 | 5.0 | 5.0 | 5.0 | 5.0 | 5.0 | 5.0 | 5.0 | 5.0 | 5.0 | 5.0 | 5.0 | 5.0 | 5.0 | 5.0 | 5.0 | 5.0 | 5.0 | 5.0 | 5.0 | 5.0 | 5.0 | 5.0 | 5.0 | 5.0 | 5.0 | 5.0 | 5.0 | 5.0 | | |
| | Monthly maximum | 0.2 | Daily average | 0.1 | 0.1 | 0.1 | 0.2 | 0.1 | 0.1 | 0.1 | 0.1 | 0.1 | 0.1 | 0.2 | 0.1 | 0.1 | 0.2 | 0.2 | 0.2 | 0.2 | 0.2 | 0.1 | 0.2 | 0.2 | 0.2 | 0.1 | 0.1 | 0.1 | 0.1 | 0.1 | 0.1 | 0.1 | 0.1 | |
| | No of invalid days | 0 | Value Valid? | Y | Y | Y | Y | Y | Y | Y | Y | Y | Y | Y | Y | Y | Y | Y | Y | Y | Y | Y | Y | Y | Y | Y | Y | Y | Y | Y | Y | Y | Y | |
| | Sum of exceedances | 0 | Value Exceeds ELV? | N | N | N | N | N | N | N | N | N | N | N | N | N | N | N | N | N | N | N | N | N | N | N | N | N | N | N | N | N | N | |

Signed.....REDACTED.....

Date.....06.10.25.....

(Authorised to sign as a representative of the Operator)


Permit Reference Number : PPC/A/1157446

Operator : Kanadevia Inova UK Operations Ltd

Installation: Earlsgate Energy Center

Form Number: Air 8 (A1)

Reporting of Continuously Monitored Emissions to Air for N2O mg/Nm3 at Emission Point A1 For the month of July 2025



| Monthly summary | | Date | 1 | 2 | 3 | 4 | 5 | 6 | 7 | 8 | 9 | 10 | 11 | 12 | 13 | 14 | 15 | 16 | 17 | 18 | 19 | 20 | 21 | 22 | 23 | 24 | 25 | 26 | 27 | 28 | 29 | 30 | 31 | |
|---------------------|-----------------------|--------------------------|-----------------------------|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|
| Half-hourly average | | Half-hourly average ELV | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A |
| | Monthly maximum | 9.7 | Maximum Half-hourly average | 4.3 | 5.8 | 6.6 | 4.5 | 6.9 | 7.0 | 5.5 | 5.1 | 5.9 | 6.7 | 5.6 | 5.6 | 6.9 | 5.0 | 8.5 | 9.7 | 7.5 | 6.7 | 5.9 | 5.0 | 6.0 | 6.5 | 5.2 | 5.7 | 2.7 | 3.0 | 5.4 | 4.2 | 4.2 | 5.6 | 4.2 |
| | Monthly mean | 3.2 | Mean Half-hourly average | 2.6 | 3.5 | 3.7 | 3.2 | 3.3 | 3.9 | 3.2 | 2.7 | 3.2 | 3.5 | 3.2 | 3.8 | 4.5 | 2.7 | 3.5 | 4.6 | 5.4 | 4.6 | 4.2 | 3.5 | 3.1 | 3.5 | 2.7 | 2.6 | 1.5 | 1.4 | 2.5 | 2.8 | 2.7 | 3.1 | 1.9 |
| | Monthly minimum | 0.4 | Minimum Half-hourly average | 1.2 | 1.1 | 2.2 | 0.9 | 1.5 | 1.2 | 0.7 | 1.2 | 1.8 | 0.9 | 0.8 | 2.3 | 2.5 | 1.1 | 0.9 | 2.8 | 3.4 | 2.3 | 2.9 | 2.1 | 1.3 | 1.7 | 1.1 | 0.9 | 0.4 | 0.5 | 0.4 | 1.2 | 1.1 | 1.5 | 0.6 |
| | Total Invalid results | 0 | No of Invalid results | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| Sum of exceedances | 0 | No of exceedances of ELV | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A |
| Daily average | | Daily average ELV | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A |
| | Monthly maximum | 5.4 | Daily average | 2.6 | 3.5 | 3.7 | 3.2 | 3.3 | 3.9 | 3.2 | 2.7 | 3.2 | 3.5 | 3.2 | 3.8 | 4.5 | 2.7 | 3.5 | 4.6 | 5.4 | 4.6 | 4.2 | 3.5 | 3.1 | 3.5 | 2.7 | 2.6 | 1.5 | 1.4 | 2.5 | 2.8 | 2.7 | 3.1 | 1.9 |
| | No of invalid days | 0 | Value Valid? | Y | Y | Y | Y | Y | Y | Y | Y | Y | Y | Y | Y | Y | Y | Y | Y | Y | Y | Y | Y | Y | Y | Y | Y | Y | Y | Y | Y | Y | Y | Y |
| | Sum of exceedances | 0 | Value Exceeds ELV? | N | N | N | N | N | N | N | N | N | N | N | N | N | N | N | N | N | N | N | N | N | N | N | N | N | N | N | N | N | N | N |

Signed.....REDACTED.....

Date.....06.10.25.....

(Authorised to sign as a representative of the Operator)


Permit Reference Number : PPC/A/1157446

Operator : Kanadevia Inova UK Operations Ltd

Installation: Earlsgate Energy Center

Form Number: Air A (A1)

Reporting of Continuously Monitored Emissions to Air for CO2 % at Emission Point A1 For the month of July 2025



| Monthly summary | | Date | 1 | 2 | 3 | 4 | 5 | 6 | 7 | 8 | 9 | 10 | 11 | 12 | 13 | 14 | 15 | 16 | 17 | 18 | 19 | 20 | 21 | 22 | 23 | 24 | 25 | 26 | 27 | 28 | 29 | 30 | 31 |
|---------------------|-----------------------|-------------------------|-----------------------------|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|----|
| Half-hourly average | | Half-hourly average ELV | 10 | 10 | 10 | 10 | 10 | 10 | 10 | 10 | 10 | 10 | 10 | 10 | 10 | 10 | 10 | 10 | 10 | 10 | 10 | 10 | 10 | 10 | 10 | 10 | 10 | 10 | 10 | 10 | 10 | 10 | 10 |
| | Monthly maximum | 9 | Maximum Half-hourly average | 8 | 8 | 8 | 8 | 8 | 8 | 8 | 8 | 8 | 8 | 8 | 8 | 8 | 8 | 8 | 8 | 8 | 8 | 8 | 8 | 8 | 8 | 8 | 8 | 8 | 8 | 8 | 8 | 8 | 8 |
| | Monthly mean | 8 | Mean Half-hourly average | 8 | 8 | 8 | 8 | 7 | 7 | 7 | 7 | 8 | 8 | 8 | 8 | 8 | 7 | 8 | 8 | 8 | 8 | 8 | 7 | 7 | 8 | 8 | 8 | 8 | 8 | 8 | 8 | 8 | 8 |
| | Monthly minimum | 6 | Minimum Half-hourly average | 7 | 7 | 8 | 7 | 7 | 7 | 7 | 7 | 8 | 8 | 8 | 6 | 7 | 7 | 7 | 8 | 7 | 7 | 7 | 7 | 7 | 7 | 8 | 7 | 7 | 8 | 8 | 8 | 8 | |
| | Total Invalid results | 0 | No of Invalid results | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| | Sum of exceedances | 0 | No of exceedances of ELV | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| Daily average | | Daily average ELV | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | |
| | Monthly maximum | 8 | Daily average | 8 | 8 | 8 | 8 | 7 | 7 | 7 | 8 | 8 | 8 | 8 | 8 | 7 | 8 | 8 | 8 | 8 | 8 | 8 | 7 | 7 | 8 | 8 | 8 | 8 | 8 | 8 | 8 | 8 | |
| | No of invalid days | 0 | Value Valid? | Y | Y | Y | Y | Y | Y | Y | Y | Y | Y | Y | Y | Y | Y | Y | Y | Y | Y | Y | Y | Y | Y | Y | Y | Y | Y | Y | Y | Y | |
| | Sum of exceedances | 0 | Value Exceeds ELV? | N | N | N | N | N | N | N | N | N | N | N | N | N | N | N | N | N | N | N | N | N | N | N | N | N | N | N | N | N | N |

Signed.....REDACTED.....

Date.....06.10.25.....

(Authorised to sign as a representative of the Operator)


Permit Reference Number : PPC/A/1157446

Operator : Kanadevia Inova UK Operations Ltd

Installation: Earlsgate Energy Center

Form Number: Air B (A1)

Reporting of Continuously Monitored Emissions to Air for Dry Oxygen % at Emission Point A1 For the month of July 2025



| Monthly summary | | Date | 1 | 2 | 3 | 4 | 5 | 6 | 7 | 8 | 9 | 10 | 11 | 12 | 13 | 14 | 15 | 16 | 17 | 18 | 19 | 20 | 21 | 22 | 23 | 24 | 25 | 26 | 27 | 28 | 29 | 30 | 31 | |
|---------------------|-----------------------|-------------------------|-----------------------------|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|
| Half-hourly average | | Half-hourly average ELV | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A |
| | Monthly maximum | 8 | Maximum Half-hourly average | 7 | 8 | 7 | 7 | 8 | 8 | 7 | 7 | 7 | 7 | 7 | 7 | 7 | 7 | 7 | 8 | 7 | 8 | 7 | 7 | 7 | 7 | 8 | 7 | 7 | 7 | 7 | 7 | 7 | 7 | |
| | Monthly mean | 7 | Mean Half-hourly average | 7 | 7 | 7 | 7 | 7 | 7 | 7 | 7 | 7 | 7 | 7 | 7 | 7 | 7 | 7 | 7 | 7 | 7 | 7 | 7 | 7 | 7 | 6 | 6 | 6 | 6 | 6 | 6 | 6 | 6 | |
| | Monthly minimum | 5 | Minimum Half-hourly average | 6 | 6 | 6 | 6 | 6 | 6 | 6 | 6 | 6 | 6 | 6 | 6 | 6 | 6 | 6 | 6 | 6 | 6 | 6 | 6 | 6 | 6 | 6 | 6 | 5 | 6 | 6 | 6 | 6 | 6 | |
| | Total Invalid results | 0 | No of Invalid results | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| | Sum of exceedances | 0 | No of exceedances of ELV | N/A |
| Daily average | | Daily average ELV | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | |
| | Monthly maximum | 7 | Daily average | 7 | 7 | 7 | 7 | 7 | 7 | 7 | 7 | 7 | 7 | 7 | 7 | 7 | 7 | 7 | 7 | 7 | 7 | 7 | 7 | 7 | 7 | 6 | 6 | 6 | 6 | 6 | 6 | 6 | 6 | |
| | No of invalid days | 0 | Value Valid? | Y | Y | Y | Y | Y | Y | Y | Y | Y | Y | Y | Y | Y | Y | Y | Y | Y | Y | Y | Y | Y | Y | Y | Y | Y | Y | Y | Y | Y | Y | |
| | Sum of exceedances | 0 | Value Exceeds ELV? | N | N | N | N | N | N | N | N | N | N | N | N | N | N | N | N | N | N | N | N | N | N | N | N | N | N | N | N | N | N | N |

Signed.....**REDACTED**.....

Date.....**06.10.25**.....

(Authorised to sign as a representative of the Operator)


Permit Reference Number : PPC/A/1157446

Operator : Kanadevia Inova UK Operations Ltd

Installation: Earlsgate Energy Center

Form Number: Air C (A1)

Reporting of Continuously Monitored Emissions to Air for Moisture % at Emission Point A1 For the month of July 2025



| Monthly summary | | Date | 1 | 2 | 3 | 4 | 5 | 6 | 7 | 8 | 9 | 10 | 11 | 12 | 13 | 14 | 15 | 16 | 17 | 18 | 19 | 20 | 21 | 22 | 23 | 24 | 25 | 26 | 27 | 28 | 29 | 30 | 31 | | |
|---------------------|-----------------------|-------------------------|-----------------------------|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|
| Half-hourly average | | Half-hourly average ELV | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | |
| | Monthly maximum | 22 | Maximum Half-hourly average | 20 | 20 | 20 | 21 | 20 | 19 | 19 | 20 | 20 | 21 | 20 | 20 | 19 | 20 | 20 | 21 | 22 | 20 | 20 | 19 | 20 | 21 | 21 | 21 | 21 | 20 | 19 | 21 | 21 | 22 | 21 | |
| | Monthly mean | 18 | Mean Half-hourly average | 17 | 17 | 17 | 17 | 16 | 16 | 17 | 18 | 18 | 18 | 18 | 17 | 17 | 17 | 18 | 19 | 18 | 18 | 18 | 17 | 18 | 18 | 18 | 18 | 18 | 17 | 17 | 18 | 18 | 18 | 18 | |
| | Monthly minimum | 13 | Minimum Half-hourly average | 16 | 14 | 15 | 14 | 13 | 15 | 14 | 14 | 16 | 16 | 16 | 14 | 16 | 15 | 16 | 17 | 17 | 16 | 16 | 16 | 15 | 16 | 16 | 14 | 14 | 14 | 16 | 16 | 16 | 16 | 14 | |
| | Total Invalid results | 0 | No of Invalid results | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| | Sum of exceedances | 0 | No of exceedances of ELV | N/A |
| Daily average | | Daily average ELV | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | |
| | Monthly maximum | 19 | Daily average | 17 | 17 | 17 | 17 | 16 | 16 | 17 | 18 | 18 | 18 | 18 | 17 | 17 | 17 | 18 | 19 | 18 | 18 | 18 | 17 | 18 | 18 | 18 | 18 | 18 | 17 | 17 | 18 | 18 | 18 | 18 | |
| | No of invalid days | 0 | Value Valid? | Y | Y | Y | Y | Y | Y | Y | Y | Y | Y | Y | Y | Y | Y | Y | Y | Y | Y | Y | Y | Y | Y | Y | Y | Y | Y | Y | Y | Y | Y | Y | |
| | Sum of exceedances | 0 | Value Exceeds ELV? | N | N | N | N | N | N | N | N | N | N | N | N | N | N | N | N | N | N | N | N | N | N | N | N | N | N | N | N | N | N | N | N |


Signed.....REDACTED.....

Date.....06.10.25.....

(Authorised to sign as a representative of the Operator)

Reporting of Continuously Monitored Emissions to Air for CO mg/Nm3 at Emission Point A1 For the month of July 2025

Daily and 10 Minute Average Monitoring Data



| Monthly summary | | Date | 1 | 2 | 3 | 4 | 5 | 6 | 7 | 8 | 9 | 10 | 11 | 12 | 13 | 14 | 15 | 16 | 17 | 18 | 19 | 20 | 21 | 22 | 23 | 24 | 25 | 26 | 27 | 28 | 29 | 30 | 31 | | |
|-------------------|--------------------------|---|---|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|---|
| 10 Minute average | | 10 Minute average ELV (95th Percentile) | 150 | 150 | 150 | 150 | 150 | 150 | 150 | 150 | 150 | 150 | 150 | 150 | 150 | 150 | 150 | 150 | 150 | 150 | 150 | 150 | 150 | 150 | 150 | 150 | 150 | 150 | 150 | 150 | 150 | 150 | 150 | | |
| | Monthly Maximum 10-min | 815 | Maximum 10 Minute average | 399 | 382 | 135 | 467 | 102 | 430 | 179 | 214 | 274 | 270 | 606 | 815 | 109 | 284 | 47 | 162 | 307 | 259 | 319 | 198 | 155 | 152 | 111 | 752 | 94 | 148 | 268 | 324 | 136 | 148 | 122 | |
| | Monthly mean 10-min avgs | 7 | 95th Percentile | 5 | 9 | 6 | 8 | 8 | 39 | 14 | 5 | 6 | 15 | 6 | 47 | 6 | 11 | 5 | 8 | 7 | 12 | 11 | 5 | 6 | 16 | 25 | 32 | 12 | 26 | 10 | 5 | 7 | 7 | 7 | |
| | Monthly Minimum 10-min | 0 | Minimum 10 Minute average | 1 | 2 | 1 | 1 | 1 | 1 | 1 | 1 | 2 | 2 | 2 | 1 | 1 | 1 | 1 | 1 | 0 | 1 | 1 | 2 | 1 | 2 | 2 | 2 | 2 | 2 | 1 | 1 | 2 | 2 | 1 | |
| | Total Invalid results | 0 | No of Invalid results | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| | | | Number of results above 150mg/m³ | 1 | 3 | 0 | 1 | 0 | 3 | 1 | 1 | 1 | 1 | 1 | 2 | 0 | 3 | 0 | 1 | 1 | 2 | 1 | 1 | 1 | 1 | 1 | 0 | 2 | 0 | 0 | 1 | 2 | 0 | 0 | 0 |
| | | | Sum of Exceedances of 95th percentile ELV | 0 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| Daily average | | Daily average ELV | 50 | 50 | 50 | 50 | 50 | 50 | 50 | 50 | 50 | 50 | 50 | 50 | 50 | 50 | 50 | 50 | 50 | 50 | 50 | 50 | 50 | 50 | 50 | 50 | 50 | 50 | 50 | 50 | 50 | 50 | 50 | 50 | |
| | Monthly maximum | 15 | Daily average | 7 | 11 | 5 | 8 | 5 | 15 | 6 | 5 | 6 | 8 | 9 | 14 | 4 | 10 | 4 | 5 | 6 | 10 | 7 | 6 | 4 | 7 | 7 | 14 | 6 | 7 | 7 | 6 | 6 | 6 | 6 | |
| | No of invalid days | 0 | Value Valid? | Y | Y | Y | Y | Y | Y | Y | Y | Y | Y | Y | Y | Y | Y | Y | Y | Y | Y | Y | Y | Y | Y | Y | Y | Y | Y | Y | Y | Y | Y | Y | |
| | Sum of exceedances | 0 | Value Exceeds ELV? (Y/N) | N | N | N | N | N | N | N | N | N | N | N | N | N | N | N | N | N | N | N | N | N | N | N | N | N | N | N | N | N | N | N | N |

Signed.....REDACTED.....

Date.....06.10.25.....

(Authorised to sign as a representative of the Operator)

Environment Agency explanatory note: The 10-minute average ELV is based on the "95th percentile" In this case this means that 95% of the 10 minute averages in the calendar day (= 137) must be below 150 mg/m3, and 5% (= 7) are allowed to be any value above 150 mg/m3. Whilst we expect operators to minimise CO emissions at all times, it is perfectly acceptable for the value of the maximum 10-minute average to be above 150 mg/m3, provided the 95th percentile ELV has been met for that period