


Permit Reference Number : PPC/A/1157446

Operator : Kanadevia Inova UK Operations Ltd

Installation: Earlsgate Energy Center

Form Number: Air A (A1)

Reporting of Continuously Monitored Emissions to Air for CO2 % at Emission Point A1 For the month of November 2025



Monthly summary		Date	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24	25	26	27	28	29	30	31
Half-hourly average		Half-hourly average ELV	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	Monthly maximum	8.6	Maximum Half-hourly average	8.2	8.2	8.2	8.3	8.3	8.3	8.3	8.4	8.3	8.2	8.4	8.2	8.4	8.4	8.4	8.5	8.6	8.5	8.5	8.5	8.3	8.3	8.3	8.4	8.4	8.3	8.2	8.3	8.3	
	Monthly mean	8.2	Mean Half-hourly average	8.1	8.0	8.1	8.1	8.2	8.1	8.2	8.2	8.2	8.1	8.1	8.1	8.2	8.2	8.2	8.3	8.4	8.3	8.3	8.3	8.3	8.2	8.1	8.1	8.3	8.2	8.1	8.1	8.1	8.1
	Monthly minimum	3.8	Minimum Half-hourly average	7.9	3.8	8.0	8.0	8.1	8.0	8.1	7.2	8.1	8.0	8.0	8.0	8.0	8.2	8.1	8.2	8.2	8.2	8.1	8.2	8.1	8.0	8.0	7.9	8.1	8.0	8.0	7.9	7.9	8.0
	Total Invalid results	0	No of Invalid results	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
	Sum of exceedances	0	No of exceedances of ELV	N/A																													
Daily average		Daily average ELV	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
	Monthly maximum	8.4	Daily average	8.1	8.0	8.1	8.1	8.2	8.1	8.2	8.2	8.2	8.1	8.1	8.1	8.2	8.2	8.2	8.3	8.4	8.3	8.3	8.3	8.3	8.2	8.1	8.1	8.3	8.2	8.1	8.1	8.1	
	No of invalid days	0	Value Valid?	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	
	Sum of exceedances	0	Value Exceeds ELV?	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	

Signed.....

Date.....

(Authorised to sign as a representative of the Operator)


Permit Reference Number : PPC/A/1157446

Operator : Kanadevia Inova UK Operations Ltd

Installation: Earlsgate Energy Center

Form Number: Air B (A1)

Reporting of Continuously Monitored Emissions to Air for Dry Oxygen % at Emission Point A1 For the month of November 2025



Monthly summary		Date	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24	25	26	27	28	29	30	31	
Half-hourly average		Half-hourly average ELV	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	Monthly maximum	10.1	Maximum Half-hourly average	6.6	6.5	6.8	6.8	6.8	6.8	7.1	10.1	6.9	6.9	7.0	7.0	7.0	7.0	7.4	7.5	6.7	6.7	6.8	7.2	7.4	7.1	7.1	7.0	6.8	7.0	7.0	6.8	7.4	6.9	
	Monthly mean	6.3	Mean Half-hourly average	6.1	6.1	6.3	6.3	6.2	6.2	6.2	6.4	6.4	6.4	6.4	6.4	6.4	6.4	6.5	6.4	6.2	6.2	6.2	6.4	6.6	6.5	6.5	6.5	6.4	6.4	6.4	6.3	6.4	6.4	
	Monthly minimum	5.2	Minimum Half-hourly average	5.6	5.5	5.6	5.6	5.6	5.5	5.7	5.6	5.2	5.9	5.9	5.7	5.9	5.9	5.5	5.9	5.8	5.6	5.6	5.7	6.0	5.9	5.6	5.8	5.8	5.9	6.0	5.8	5.9	5.9	
	Total Invalid results	0	No of Invalid results	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
	Sum of exceedances	0	No of exceedances of ELV	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A							
Daily average		Daily average ELV	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
	Monthly maximum	6.6	Daily average	6.1	6.1	6.3	6.3	6.2	6.2	6.2	6.4	6.4	6.4	6.4	6.4	6.4	6.5	6.4	6.2	6.2	6.2	6.4	6.6	6.5	6.5	6.5	6.4	6.4	6.4	6.3	6.4	6.4		
	No of invalid days	0	Value Valid?	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	
	Sum of exceedances	0	Value Exceeds ELV?	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	

Signed.....

Date.....

(Authorised to sign as a representative of the Operator)


Permit Reference Number : PPC/A/1157446

Operator : Kanadevia Inova UK Operations Ltd

Installation: Earlsgate Energy Center

Form Number: Air C (A1)

Reporting of Continuously Monitored Emissions to Air for Moisture % at Emission Point A1 For the month of November 2025



Monthly summary		Date	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24	25	26	27	28	29	30	31
Half-hourly average		Half-hourly average ELV	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	Monthly maximum	22.8	Maximum Half-hourly average	19.8	20.0	22.2	21.3	22.0	22.1	22.0	21.5	20.6	20.7	21.4	21.5	20.8	21.7	20.5	21.2	22.7	22.8	22.0	22.6	22.8	21.3	21.9	22.2	20.7	20.7	20.4	19.9	19.2	21.5
	Monthly mean	18.6	Mean Half-hourly average	17.9	17.8	19.2	19.1	19.1	19.1	19.1	18.4	18.5	18.4	18.7	18.6	18.6	18.9	17.8	18.3	19.2	19.7	19.5	19.0	18.3	18.0	18.3	18.4	18.7	18.3	18.5	18.1	17.5	17.7
	Monthly minimum	8.1	Minimum Half-hourly average	15.1	8.1	17.6	16.4	16.8	17.2	17.2	12.7	17.6	15.7	17.2	16.8	16.8	17.0	15.2	15.9	17.5	17.9	18.0	16.7	14.1	15.6	16.9	16.4	15.2	16.6	16.2	15.5	14.6	16.2
	Total Invalid results	0	No of Invalid results	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
Sum of exceedances	0	No of exceedances of ELV	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Daily average		Daily average ELV	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	Monthly maximum	19.7	Daily average	17.9	17.8	19.2	19.1	19.1	19.1	18.4	18.5	18.4	18.7	18.6	18.6	18.9	17.8	18.3	19.2	19.7	19.5	19.0	18.3	18.0	18.3	18.4	18.7	18.3	18.5	18.1	17.5	17.7	
	No of invalid days	0	Value Valid?	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	
	Sum of exceedances	0	Value Exceeds ELV?	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N


Signed.....

Date.....

(Authorised to sign as a representative of the Operator)

Reporting of Continuously Monitored Emissions to Air for CO mg/Nm3 at Emission Point A1 For the month of November 2025

Daily and 10 Minute Average Monitoring Data



Monthly summary		Date	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24	25	26	27	28	29	30	31	
10 Minute average		10 Minute average ELV (95th Percentile)	150	150	150	150	150	150	150	150	150	150	150	150	150	150	150	150	150	150	150	150	150	150	150	150	150	150	150	150	150	150	150	
	Monthly Maximum 10-min	741	Maximum 10 Minute average	741	74	300	88	86	15	83	365	484	75	15	309	532	14	470	390	8	70	70	428	124	101	165	144	310	219	185	71	638	645	
	Monthly mean 10-min avgs	8	95th Percentile	11	11	9	19	9	8	9	8	9	6	9	37	10	7	13	8	6	14	7	27	6	10	13	7	11	11	10	12	28	16	
	Monthly Minimum 10-min	0	Minimum 10 Minute average	3	0	3	2	3	2	2	3	3	1	2	2	2	3	2	2	2	2	2	1	2	2	2	1	1	2	2	2	2	2	
	Total Invalid results	1	No of Invalid results	0	1	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
			Number of results above 150mg/m³	2	0	1	0	0	0	0	0	2	1	0	0	2	2	0	2	1	0	0	0	2	0	0	1	0	1	2	1	0	3	2
		Sum of Exceedances of 95th percentile ELV	0	95th Percentile ELV Exceeded (Y/N)																														
Daily average		Daily average ELV	50	50	50	50	50	50	50	50	50	50	50	50	50	50	50	50	50	50	50	50	50	50	50	50	50	50	50	50	50	50	50	
	Monthly maximum	14	Daily average	14	7	9	8	6	5	7	11	9	4	5	11	11	5	12	8	4	6	5	12	6	6	6	6	9	10	9	7	13	11	
	No of invalid days	0	Value Valid?	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	
	Sum of exceedances	0	Value Exceeds ELV? (Y/N)	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N

Signed.....

Date.....

(Authorised to sign as a representative of the Operator)

Environment Agency explanatory note: The 10-minute average ELV is based on the "95th percentile" In this case this means that 95% of the 10 minute averages in the calendar day (= 137) must be below 150 mg/m3, and 5% (= 7) are allowed to be any value above 150 mg/m3. Whilst we expect operators to minimise CO emissions at all times, it is perfectly acceptable for the value of the maximum 10-minute average to be above 150 mg/m3, provided the 95th percentile ELV has been met for that period

Permit Reference Number : PPC/A/1157446


Operator : Kanadevia Inova UK Operations Ltd

Installation: Earlsgate Energy Center

Form Number: Air 3 (A1)

Reporting of Continuously Monitored Emissions to Air for HCl mg/Nm3 at Emission Point A1 For the month of November 2025

Daily and Half-hourly Average Monitoring Data



Monthly summary		Date	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24	25	26	27	28	29	30	31	
Half-hourly average		Half-hourly average ELV	60.0	60.0	60.0	60.0	60.0	60.0	60.0	60.0	60.0	60.0	60.0	60.0	60.0	60.0	60.0	60.0	60.0	60.0	60.0	60.0	60.0	60.0	60.0	60.0	60.0	60.0	60.0	60.0	60.0	60.0		
	Monthly maximum	8.9	Maximum Half-hourly average	7.2	7.4	7.7	7.3	7.3	7.1	6.5	8.7	4.0	4.8	4.5	4.8	6.4	7.6	7.5	7.1	7.4	7.4	7.2	8.9	7.1	5.5	7.1	7.5	7.7	7.3	5.4	3.5	4.1	4.1	
	Monthly mean	5.0	Mean Half-hourly average	6.4	6.7	6.1	5.3	5.7	6.2	5.2	4.8	2.7	3.1	3.3	3.3	5.1	6.5	5.7	5.9	6.4	6.5	5.8	5.5	4.6	4.4	5.8	6.5	6.5	5.8	3.7	2.5	2.7	2.9	
	Monthly minimum	1.7	Minimum Half-hourly average	5.7	3.2	5.1	3.8	4.6	5.4	4.6	2.4	1.7	2.6	2.3	2.4	3.9	5.1	4.6	4.7	5.3	4.8	4.7	4.5	3.5	3.8	4.4	5.5	5.5	4.6	2.6	2.1	2.0	2.4	
	Total Invalid results	0	No of Invalid results	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
	Sum of exceedances	0	No of exceedances of ELV	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
Daily average		Daily average ELV	8.0	8.0	8.0	8.0	8.0	8.0	8.0	8.0	8.0	8.0	8.0	8.0	8.0	8.0	8.0	8.0	8.0	8.0	8.0	8.0	8.0	8.0	8.0	8.0	8.0	8.0	8.0	8.0	8.0	8.0	8.0	
	Monthly maximum	6.7	Daily average	6.4	6.7	6.1	5.3	5.7	6.2	5.2	4.8	2.7	3.1	3.3	3.3	5.1	6.5	5.7	5.9	6.4	6.5	5.8	5.5	4.6	4.4	5.8	6.5	6.5	5.8	3.7	2.5	2.7	2.9	
	No of invalid days	0	Value Valid?	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	
	Sum of exceedances	0	Value Exceeds ELV?	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	

Signed.....

Date.....

(Authorised to sign as a representative of the Operator)


Permit Reference Number : PPC/A/1157446

Operator : Kanadevia Inova UK Operations Ltd

Installation: Earlsgate Energy Center

Form Number: Air 5 (A1)

Reporting of Continuously Monitored Emissions to Air for SO2 mg/Nm3 at Emission Point A1 For the month of November 2025



Monthly summary		Date	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24	25	26	27	28	29	30	31	
Half-hourly average		Half-hourly average ELV	200	200	200	200	200	200	200	200	200	200	200	200	200	200	200	200	200	200	200	200	200	200	200	200	200	200	200	200	200	200	200	
	Monthly maximum	246	Maximum Half-hourly average	11	7	7	12	10	9	7	246	57	31	11	9	7	7	19	7	5	5	6	26	19	11	9	7	6	5	15	15	27	14	
	Monthly mean	6	Mean Half-hourly average	7	5	5	6	5	6	5	18	16	7	6	6	5	5	6	5	4	5	5	6	5	6	6	5	4	5	6	6	7	5	
	Monthly minimum	1	Minimum Half-hourly average	5	1	4	4	4	4	4	4	4	4	4	4	5	3	4	4	4	4	4	4	4	4	4	5	4	4	4	4	4	4	
	Total Invalid results	0	No of Invalid results	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
	Sum of exceedances	1	No of exceedances of ELV	0	0	0	0	0	0	0	0	1	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
Daily average		Daily average ELV	40	40	40	40	40	40	40	40	40	40	40	40	40	40	40	40	40	40	40	40	40	40	40	40	40	40	40	40	40	40	40	
	Monthly maximum	18	Daily average	7	5	5	6	5	6	5	18	16	7	6	6	5	5	6	5	4	5	5	6	5	6	6	5	4	5	6	6	7	5	
	No of invalid days	0	Value Valid?	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	
	Sum of exceedances	0	Value Exceeds ELV?	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N

Signed.....

Date.....

(Authorised to sign as a representative of the Operator)

Permit Reference Number : PPC/A/1157446


Operator : Kanadevia Inova UK Operations Ltd

Installation: Earlsgate Energy Center

Form Number: Air 6 (A1)

Reporting of Continuously Monitored Emissions to Air for NOx mg/Nm3 at Emission Point A1 For the month of November 2025

Daily and Half-hourly Average Monitoring Data



Monthly summary		Date	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24	25	26	27	28	29	30	31	
Half-hourly average		Half-hourly average ELV	400	400	400	400	400	400	400	400	400	400	400	400	400	400	400	400	400	400	400	400	400	400	400	400	400	400	400	400	400	400	400	
	Monthly maximum	183	Maximum Half-hourly average	168	173	167	166	166	163	171	163	162	169	166	168	168	172	166	164	166	167	175	178	168	161	160	169	168	183	164	166	172	163	
	Monthly mean	152	Mean Half-hourly average	153	151	153	152	152	152	152	152	152	152	152	152	152	153	151	152	151	152	153	152	152	150	152	152	152	152	152	152	152	152	
	Monthly minimum	73	Minimum Half-hourly average	143	73	141	134	138	141	135	131	124	136	139	138	129	137	129	135	119	130	129	122	136	121	143	140	137	104	136	131	138	137	
	Total Invalid results	0	No of Invalid results	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
	Sum of exceedances	0	No of exceedances of ELV	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
Daily average		Daily average ELV	180	180	180	180	180	180	180	180	180	180	180	180	180	180	180	180	180	180	180	180	180	180	180	180	180	180	180	180	180	180		
	Monthly maximum	153	Daily average	153	151	153	152	152	152	152	152	152	152	152	152	153	151	152	151	152	153	152	152	150	152	152	152	152	152	152	152	152		
	No of invalid days	0	Value Valid?	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y		
	Sum of exceedances	0	Value Exceeds ELV?	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	

Signed.....

Date.....

(Authorised to sign as a representative of the Operator)


Permit Reference Number : PPC/A/1157446

Operator : Kanadevia Inova UK Operations Ltd

Installation: Earlsgate Energy Center

Form Number: Air 2 (A1)

Reporting of Continuously Monitored Emissions to Air for TOC mg/Nm3 at Emission Point A1 For the month of November 2025



Monthly summary		Date	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24	25	26	27	28	29	30	31	
Half-hourly average		Half-hourly average ELV	20.0	20.0	20.0	20.0	20.0	20.0	20.0	20.0	20.0	20.0	20.0	20.0	20.0	20.0	20.0	20.0	20.0	20.0	20.0	20.0	20.0	20.0	20.0	20.0	20.0	20.0	20.0	20.0	20.0	20.0		
	Monthly maximum	26.8	Maximum Half-hourly average	8.9	5.6	5.4	4.8	12.7	5.0	5.2	9.4	20.4	4.8	3.4	5.1	7.1	4.9	26.8	6.7	4.4	3.7	3.6	5.0	4.4	4.8	4.6	3.7	4.9	4.0	4.4	5.1	6.3	5.4	
	Monthly mean	3.5	Mean Half-hourly average	4.4	4.5	4.2	3.7	4.1	3.8	3.9	4.1	4.5	3.1	2.7	3.3	3.6	3.5	4.3	4.3	3.5	2.9	2.8	3.0	3.0	3.3	3.1	2.8	3.0	2.9	3.3	3.3	3.4	2.9	
	Monthly minimum	1.0	Minimum Half-hourly average	3.1	3.5	3.0	2.4	2.7	2.5	2.5	3.1	3.1	1.0	1.7	2.3	1.7	2.6	2.6	2.8	2.8	2.1	2.1	1.9	2.1	1.8	2.5	2.1	1.5	2.2	1.9	2.2	2.3	2.1	
	Total Invalid results	0	No of Invalid results	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
	Sum of exceedances	2	No of exceedances of ELV	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	1	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
Daily average		Daily average ELV	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0		
	Monthly maximum	4.5	Daily average	4.4	4.5	4.2	3.7	4.1	3.8	3.9	4.1	4.5	3.1	2.7	3.3	3.6	3.5	4.3	4.3	3.5	2.9	2.8	3.0	3.0	3.3	3.1	2.8	3.0	2.9	3.3	3.3	3.4	2.9	
	No of invalid days	0	Value Valid?	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y		
	Sum of exceedances	0	Value Exceeds ELV?	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	

Signed.....

Date.....

(Authorised to sign as a representative of the Operator)

Permit Reference Number : PPC/A/1157446


Operator : Kanadevia Inova UK Operations Ltd

Installation: Earlsgate Energy Center

Form Number: Air 7 (A1)

Reporting of Continuously Monitored Emissions to Air for NH3 mg/Nm3 at Emission Point A1 For the month of November 2025

Daily and Half-hourly Average Monitoring Data



Monthly summary		Date	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24	25	26	27	28	29	30	31		
Half-hourly average		Half-hourly average ELV	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
	Monthly maximum	2.5	Maximum Half-hourly average	0.1	0.1	0.2	0.1	0.2	0.1	0.1	2.5	1.4	0.3	0.2	0.2	0.2	0.1	0.2	0.1	0.1	0.1	0.1	0.1	0.4	0.2	0.2	0.2	0.2	0.1	0.2	0.5	0.2	0.3	0.4	
	Monthly mean	0.1	Mean Half-hourly average	0.0	0.0	0.1	0.1	0.0	0.0	0.0	0.2	0.2	0.2	0.1	0.1	0.0	0.0	0.1	0.0	0.0	0.0	0.0	0.1	0.1	0.1	0.1	0.1	0.0	0.1	0.1	0.1	0.1	0.1	0.1	
	Monthly minimum	0.0	Minimum Half-hourly average	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.1	0.1	0.1	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	
	Total Invalid results	0	No of Invalid results	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
	Sum of exceedances	0	No of exceedances of ELV	N/A	N/A																														
Daily average		Daily average ELV	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	
	Monthly maximum	0.2	Daily average	0.0	0.0	0.1	0.1	0.0	0.0	0.0	0.2	0.2	0.2	0.1	0.1	0.0	0.0	0.1	0.0	0.0	0.0	0.0	0.1	0.1	0.1	0.1	0.1	0.0	0.1	0.1	0.1	0.1	0.1	0.1	
	No of invalid days	0	Value Valid?	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	
	Sum of exceedances	0	Value Exceeds ELV?	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N

Signed.....

Date.....

(Authorised to sign as a representative of the Operator)

Permit Reference Number : PPC/A/1157446


Operator : Kanadevia Inova UK Operations Ltd

Installation: Earlsgate Energy Center

Form Number: Air 1 (A1)

Reporting of Continuously Monitored Emissions to Air for Particulates mg/Nm3 at Emission Point A1 For the month of November 2025

Daily and Half-hourly Average Monitoring Data



Monthly summary		Date	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24	25	26	27	28	29	30	31			
Half-hourly average		Half-hourly average ELV	30.0	30.0	30.0	30.0	30.0	30.0	30.0	30.0	30.0	30.0	30.0	30.0	30.0	30.0	30.0	30.0	30.0	30.0	30.0	30.0	30.0	30.0	30.0	30.0	30.0	30.0	30.0	30.0	30.0	30.0	30.0			
	Monthly maximum	0.3	Maximum Half-hourly average	0.2	0.1	0.2	0.2	0.2	0.1	0.2	0.2	0.2	0.2	0.2	0.2	0.1	0.2	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.2	0.2	0.3	0.2	0.2	0.1	0.2	0.1	0.1	0.1	0.1	
	Monthly mean	0.1	Mean Half-hourly average	0.1	0.1	0.1	0.2	0.1	0.1	0.1	0.1	0.1	0.2	0.2	0.2	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.2	0.2	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	
	Monthly minimum	0.0	Minimum Half-hourly average	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.0	0.1	0.0	0.0	0.0	
	Total Invalid results	0	No of Invalid results	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
	Sum of exceedances	0	No of exceedances of ELV	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
Daily average		Daily average ELV	5.0	5.0	5.0	5.0	5.0	5.0	5.0	5.0	5.0	5.0	5.0	5.0	5.0	5.0	5.0	5.0	5.0	5.0	5.0	5.0	5.0	5.0	5.0	5.0	5.0	5.0	5.0	5.0	5.0	5.0	5.0	5.0		
	Monthly maximum	0.2	Daily average	0.1	0.1	0.1	0.2	0.1	0.1	0.1	0.1	0.1	0.2	0.2	0.2	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.2	0.2	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	
	No of invalid days	0	Value Valid?	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	
	Sum of exceedances	0	Value Exceeds ELV?	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N

Signed.....

Date.....

(Authorised to sign as a representative of the Operator)


Permit Reference Number : PPC/A/1157446

Operator : Kanadevia Inova UK Operations Ltd

Installation: Earlsgate Energy Center

Form Number: Air 8 (A1)

Reporting of Continuously Monitored Emissions to Air for N2O mg/Nm3 at Emission Point A1 For the month of November 2025



Monthly summary		Date	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24	25	26	27	28	29	30	31	
Half-hourly average		Half-hourly average ELV	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
	Monthly maximum	17.8	Maximum Half-hourly average	4.1	2.8	4.3	5.6	5.2	4.2	5.2	17.8	4.3	4.8	5.1	4.2	4.8	3.6	4.5	5.6	3.0	4.5	3.3	6.5	6.1	5.1	4.1	4.2	3.2	4.9	3.3	3.3	3.3	2.5	
	Monthly mean	2.5	Mean Half-hourly average	2.5	2.0	2.9	3.4	2.9	2.8	3.0	3.3	2.8	2.9	2.7	2.7	2.4	2.2	2.2	2.2	1.6	2.1	2.0	3.0	2.8	2.4	3.0	2.7	1.9	1.9	2.0	1.8	2.0	1.7	
	Monthly minimum	0.4	Minimum Half-hourly average	1.6	0.7	1.4	1.3	1.4	1.1	1.5	1.5	1.6	1.9	1.6	1.8	1.2	1.0	0.8	0.9	0.7	0.6	1.1	1.3	1.2	0.7	1.1	1.4	0.8	0.4	1.0	0.5	1.0	1.1	
	Total Invalid results	0	No of Invalid results	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
	Sum of exceedances	0	No of exceedances of ELV	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A							
Daily average		Daily average ELV	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
	Monthly maximum	3.4	Daily average	2.5	2.0	2.9	3.4	2.9	2.8	3.0	3.3	2.8	2.9	2.7	2.7	2.4	2.2	2.2	2.2	1.6	2.1	2.0	3.0	2.8	2.4	3.0	2.7	1.9	1.9	2.0	1.8	2.0	1.7	
	No of invalid days	0	Value Valid?	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	
	Sum of exceedances	0	Value Exceeds ELV?	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N

Signed.....

Date.....

(Authorised to sign as a representative of the Operator)